

Georgia Power Company
230 Peachtree Street
Post Office Box 4545
Atlanta, Georgia 30303
Telephone 404 522-6060

USNRC REGION II
ATLANTA, GEORGIA

Power Supply Engineering and Services

Sup
19 ~~11~~ 1 11:11


Georgia Power
the southern electric system

May 29, 1979

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, GA 30303

REFERENCE:
RII: JPO
50-424
50-425


Attn: Mr. James P. O'Reilly

Gentlemen:

The following is submitted in response to your letter dated April 17, 1979, concerning I.E. Bulletin 79-09.

Georgia Power Company is not using General Electric type AK-2 circuit breakers in any safety related systems at Plant Vogtle Units 1 and 2.

Very truly yours,


R. W. Staffa
Manager Quality Assurance

CWH:aaw

xc: U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D.C. 20555

M. D. Hunt - USNRC, Region II

J. H. Miller, Jr.
W. E. Ehrensperger
F. G. Mitchell, Jr.
C. F. Whitmer
R. J. Kelly
R. E. Conway
D. E. Dutton
J. T. Beckham, Jr.
K. M. Gillespie
C. W. Hayes
E. D. Groover
D. L. McCrary
R. A. Thomas
M. Z. Jeric

File: X7BC24
Log: GM-459

304 036
7907090 144 9
790070