

TEXAS UTILITIES GENERATING COMPANY

2001 BRYAN TOWER - DALLAS, TEXAS 75201

July 13, 1979
TXX-3008

R. J. GARY
EXECUTIVE VICE PRESIDENT
AND GENERAL MANAGER

Mr. W. C. Seidle, Chief
Reactor Construction & Engineering
Support Branch
U. S. Nuclear Regulatory Commission
Office of Inspection & Enforcement
611 Ryan Plaza Dr., Suite 1000
Arlington, Texas 76012

Docket Nos. 50-445
50-446


COMANCHE PEAK STEAM ELECTRIC STATION
1981-33 2300 MW INSTALLATION
POSSIBLE COOLING PROBLEM WITH DIESEL GENERATOR
FILE NO. 10110

Dear Mr. Seidle:

On June 14, 1979, we verbally informed your Mr. R. G. Taylor of a possible cooling problem with the diesel generators. We considered this "potentially" reportable under 10 CFR 50.45(e).

We are continuing our investigation and evaluation and will notify you as soon as we have reached a conclusion.

Very truly yours,


R. J. Gary

RJG:ljfj

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement - (15 copies)
c/o Distribution Services Branch, DDC, ADM.
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

7907190216

343 056