

ILLINOIS POWER COMPANY



U-0094
L08-79(05-29)-9
500 SOUTH 27TH STREET, DECATUR, ILLINOIS 62525

May 29, 1979

Mr. James G. Keppler
Director, Region III
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Gler Ellyn, Illinois 60137

Dear Mr. Keppler:

Clinton Power Station Units 1 & 2
Docket Nos. 50-461 and 50-462
Construction Permits No. CPPR-137 & CPPR-138

IE Bulletin No. 79-04 reported that improper weights for check valves produced by Velan Engineering Corporation were used for some seismic analyses and requested information from licensees on their applications of Velan check valves.

No Velan check valves are to be used in the Clinton Power Station.

Sincerely,

G. E. Wuller
Supervisor - Licensing
Generation Engineering Department

PEW/jh

cc: Director, Division of Reactor Construction Inspection
Office of Inspection & Enforcement, USNRC

343 154

01 1979

7907190250