

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200

TRUSTEES

FREDERICK R. CLARK
CHAIRMAN

GEORGE L. INGALLS
VICE CHAIRMAN

RICHARD M. FLYNN

ROBERT I. MILLONZI

WILLIAM F. LUDDY



May 18, 1979
JPN-79-29

GEORGE T. BERRY
EXECUTIVE DIRECTOR

LEWIS R. BENNETT
GENERAL COUNSEL AND
ASSISTANT EXECUTIVE
DIRECTOR

JOSEPH R. SCHMIEDER
CHIEF ENGINEER

JOHN W. BOSTON
DIRECTOR OF
POWER OPERATIONS

THOMAS F. McGRANN, JR.
CONTROLLER

Director of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. Thomas A. Ippolito, Chief
Operating Reactors Branch No. 3
Division of Operating Reactors

Subject: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
Proposed Technical Specification Amendment Relating to
Inspection & Enforcement Bulletin No. 79-08

Reference: Response to I & E Bulletin No. 79-08
John D. Leonard, Jr. to Boyce H. Grier
Dated April 25, 1979 (JAFP-79-207)

Dear Sir:

During the review associated with Bulletin 79-08, the Authority's staff determined that several minor non-safety related technical specification amendments are required. Since the deficiencies which were discovered as part of the review do not relate to the requirements of Bulletin 79-08, the actual submittal of the proposed amendments will not be made during the 30 days indicated in the subject bulletin. This matter has been discussed with Region 1 I & E personnel.

The Authority currently has under development, an amendment proposal which corrects a number of the instrumentation tables contained in the technical specifications and this submittal will include the discrepancies that were identified as part of the review for Bulletin 79-08.

For your information, a brief summary of these non-safety related discrepancies is tabulated below:

- 1) Table 3.7-1 (Page 199) - Penetration X-13A & B: The table lists isolation "H" as one of the signals which requires isolation of penetration X-13A & B. This isolation signal was part of the LPCI loop selection logic that was

343 239


7907190278

physically removed from the LPCI system installed in the FitzPatrick Plant during 1976. Thus, isolation "H" should be deleted from the FitzPatrick Technical Specifications.

- 2) Table 3.7-1 (Page 203) - Penetrations X-21, 22 and 61 are currently classified as group "B" penetrations. Group "B" penetrations are defined as those penetrations containing process lines which penetrate the primary containment and are open to the free space of the containment. For each of these three penetrations which serve the instrument, breathing and service air systems to the primary containment, the systems within the containment are closed: that is, they do not communicate directly to the containment free space. Thus they should be re-classified as Group "C" penetrations. Group "C" penetrations are defined as those in which process lines which penetrate the primary containment and communicate with a closed system in the containment.

The Authority plans to submit a technical specification amendment correcting these deficiencies by July 15, 1979.

Very truly yours,



Paul J. Early
Assistant Chief Engineer-Projects

cc: Boyce H. Grier, Director
U. S. Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406