



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39201

June 1, 1979

PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission

Region II

101 Marietta Street, Suite 3100

Atlanta, Georgia 30303

ATTENTION: Mr. J. P. O'Reilly, Director

Gentlemen:

SUBJECT: Grand Gulf Nuclear Station  
File 0270/0494/15521  
Unit 1 and 2  
RII: JJB  
50-416, 417/79-07  
IE Inspection Report of  
April 3-6, 1979  
AECM-79/58

(1) Corrective Steps Taken and Results Achieved

MP&L issued D&CR 1132 on 4/5/79, documenting that the installation of the Main Steam Moment Guides in the Auxiliary Building exterior wall was not being performed in accordance with the latest revision of the design drawings. As a result of D&CR 1132, Bechtel issued NCR 3511 on 4/5/79 to track the nonconformance. NCR 3511 was closed on 4/10/79. The design drawing (9645-C-1310E) was issued reflecting a design change. D&CR 1132 was closed out by MP&L on 5/10/79.

(2) Corrective Steps Taken to Avoid Further Noncompliance

All Unit I Civil Field Engineers were reinstructed in the program requirement.

(3) Data to Achieve Full Compliance

Full compliance was achieved 4/11/79.

We find no proprietary data contained in the inspection report.

Yours truly,

L. F. Dale  
Nuclear Project Manager

JRF/pa

cc: Mr. R. B. McGehee  
Mr. T. B. Conner

Dr. Ernst Volgenau, Director  
Division of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

7907190303

343 261

7900/22

Member Middle South Utilities System

ORIGINAL COPY

USNRC REGION II  
ATLANTA, GEORGIA

JUN 6 AIO: 33