

LICENSEE EVENT REPORT

CONTROL BLOCK: 

--	--	--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

5 1 | G | A | E | I | H | 1 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 1 | 4 | 57 CAT 90

LICENSEE CODE      LICENSE NUMBER      LICENSE TYPE

CON'T

REPORT SOURCE L 5 0 5 0 0 0 3 2 1 7 0 6 2 4 7 9 8 0 7 1 2 7 9 0

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While shutdown for refueling, the 1C41-F049A relief valve lifted at 1200 psig during

0 3 | the performance of procedure HNP-1-3702 (Standby Liquid Control Pump Operability Test

0 4 | and Relief Valve Test). The valve should have relieved at 1325 ± 75 psig per Technic-

0 5 | al Specification 4.4.A.2.a. Public health and safety nor safe plant operation were

0 6 | affected by this incident.

0 7 |

SYSTEM CODE P 11		CAUSE CODE E 12		CAUSE SUBCODE D 13		COMPONENT CODE V A L V E X 14		COMP SUBCODE P 15		VALVE SUBCODE 8 16	
LER/RO REPORT NUMBER 17		EVENT YEAR 7 9		SEQUENTIAL REPORT NO. 0 4 5		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0	
ACTION TAKEN E 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23	
NPRD-A FORM SUB. Y 24		PRIME COMP SUPPLIER N 25		COMPONENT MANUFACTURER L 26		27		28		29	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (17)

10	The lifting of the relief valve at 1200 psig was caused by corrosion build-up in the
11	valve. The valve was disassembled and all moving parts thoroughly cleaned. After re-
12	assembly the valve was reset to relieve at 1380 psig.
13	
14	

80

7	8	9	FACILITY STATUS [1][5] [B] (30)	% POWER [0][0][0] (29)	OTHER STATUS N/A (30)	METHOD OF DISCOVERY [B] (31)	DISCOVERY DESCRIPTION Surveillance Test (32)
7	8	9	ACTIVITY CONTENT RELEASED OF RELEASE [1][6] [Z] (33) [Z] (34)	AMOUNT OF ACTIVITY N/A (35)	LOCATION OF RELEASE N/A (36)		
7	8	9	PERSONNEL EXPOSURES NUMBER TYPE [1][7] [0][0][0] (37) [Z] (38)	DESCRIPTION N/A (39)			
7	8	9	PERSONNEL INJURIES NUMBER DESCRIPTION [1][4] [0][0][0] (40)	N/A (41)	359	180	
7	8	9	LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION [1][0] [Z] (42)	N/A (43)			
7	8	9	PUBLICITY [2][0] [N] (44)	790723 0541 (45)	NRC USE ONLY		