

ATTACHMENT 1

NRC DOCKET 50-366
OPERATING LICENSE NPF-5
EDWIN I. HATCH NUCLEAR PLANT UNIT 2
PROPOSED CHANGES TO TECHNICAL SPECIFICATIONS

Pursuant to 10 CFR 170.12 (c) Georgia Power Company has evaluated the attached proposed amendment to Operat License NPF-5 and have determined that:

- a) The proposed amendment does not require the evaluation of a new Safety Analysis Report or rewrite of the facility license;
- b) The proposed amendment does not contain several complex issues, does not involve ACRS review, or does not require an environmental impact statement;
- c) The proposed amendment does not involve a complex issue, an environmental issue or more than one safety issue;
- d) The proposed amendment does involve a single issue, namely, the increase of the average drywell temperature limits; and
- e) The proposed amendment is therefore a Class III amendment.

424 266

7907270 195. P

ATTACHMENT 2

NRC DOCKET 50-366
OPERATING LICENSE NPF-5
EDWIN F. HATCH NUCLEAR PLANT UNIT 2
PROPOSED CHANGES TO TECHNICAL SPECIFICATIONS

The proposed change to the Technical Specifications (Appendix A to Operating License NPF-5) would be incorporated as follows:

Remove Page

3/4 6-10

Insert Page

3/4 6-10

CONTAINMENT SYSTEMS

DRYWELL AVERAGE AIR TEMPERATURE

LIMITING CONDITION FOR OPERATION

3.6.1.7 Drywell average air temperature shall not exceed 145°F.

APPLICABILITY: CONDITIONS 1, 2 and 3.

ACTION:

With the drywell average air temperature > 145°F, reduce the average air temperature to within the limit within 8 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.7 The drywell average air temperature shall be the volumetric average of the temperatures at the following drywell elevations and shall be determined to be within the limit at least once per 24 hours:

<u>Elevation</u>	<u>Azimuth</u>
a. 128-130 feet	115° or 255° or 315° or 320°
b. 162 feet	90° or 270°
c. 175 feet	90° or 270°
d. 187 feet	90° or 270°

424 268