

TERA

TERA

UNION ELECTRIC COMPANY

1901 GRATIOT STREET
ST. LOUIS, MISSOURI

June 14, 1979

JOHN K. BRYAN
VICE PRESIDENTMAILING ADDRESS:
P. O. BOX 149
ST. LOUIS, MISSOURI 63166

Mr. James G. Keppler
Regional Director, Region III
United States Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

ULNRC- 319
Callaway Plant
Units 1 & 2

Dear Mr. Keppler:

NUCLEAR REGULATORY COMMISSION IE BULLETIN NO. 79-09Reference: J. G. Keppler letter April 17, 1979

Your letter dated April 17, 1979, forwarded the subject IE Bulletin. This Bulletin concerns the use of General Electric type AK-2 circuit breakers in safety related systems. Bechtel Power Corporation, the architect engineer for Callaway Plant, Units 1 & 2, has determined that our design does not utilize this type of circuit breaker in the NSSS or balance of plant portions of the Plant. Since none of these circuit breakers are used or are planned for use, Items 2 and 3 of this Bulletin are not applicable.

If you have further questions in this matter, please contact us.

Very truly yours,



John K. Bryan

DES/kml

cc: NRC Office of Inspection and Enforcement
N. A. Petrick
J. L. Turdera

569328

JN 20 1979

7907300576