



**PUBLIC  
SERVICE  
INDIANA**

S. W. Shields  
Vice President - Electric System

June 15, 1979

Mr. James G. Keppler, Director  
U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Docket Nos.: STN 50-546  
STN 50-547  
Construction  
Permit Nos.: CPPR-170  
CPPR-171

Marble Hill Nuclear Generating Station, Units 1 & 2  
I&E Bulletin No. 79-09

Dear Mr. Keppler:

This is in response to I&E Bulletin No. 79-09, which is due June 16, 1979.

Public Service Company of Indiana, Inc. (PSI) wishes to inform you that General Electric AK-2-50 circuit breakers are planned for use in a safety-related system at the Marble Hill Nuclear Generating Station, Units 1 & 2. It has been determined that subject circuit breakers will be used as battery disconnect circuit breakers on the 125 V DC Distribution Centers.

However, the only trip function of the General Electric AK-2-50 circuit breakers at Marble Hill will be internally detected overcurrent. This is not the potential failure mode of undervoltage trip described in this I&E Bulletin No. 79-09. Therefore, no specific preventive maintenance program need be developed in response to I&E Bulletin No. 79-09.

Sincerely,

S. W. Shields  
Vice President - Electric System

PAB:ibo

cc: U. S. Nuclear Regulatory Commission  
Office of Inspection & Enforcement  
Division of Reactor Construction Inspection  
Washington, D.C. 20555

490 194

Mr. Edward R. Schwabitz  
U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

18 1979

7907300553