

10 A. W. Dromerick X-27100

NRC Bethesda 492-7617

from RM Neil

VIRGINIA ELECTRIC AND POWER COMPANY

RICHMOND, VIRGINIA 23261

June 29, 1979

(NRC PUBLIC DOCUMENT ROOM)

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. D. D. Parr, Chief
Light Water Reactors Branch No. 3
Division of Project Management
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Serial No. 526
LQA/RMN:esh

Docket Nos. 50-338
50-339

License No. NPF-4

Dear Mr. Denton:

ADDITIONAL INFORMATION ON
HIGH DENSITY SPENT FUEL RACKS

Mr. A. W. Dromerick, a member of your staff, has asked by phone about the minimum center to center spacing between fuel assemblies in adjacent high density spent fuel racks. This spacing is 14½ inches assuming the two racks are as close as possible.

Very truly yours,

W. C. Stallings
W. C. Stallings

Vice President-Power Supply
and Production Operations

cc: Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
Region II

U.S. NUCLEAR REGULATORY COMMISSION

POOR ORIGINAL

7907310451

P/A