



Duquesne Light

435 Sixth Avenue
Pittsburgh, Pa.
15219

(412) 456-6000

DUQUESNE LIGHT COMPANY
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15077

July 26, 1979
BVPS:JAW:693

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
LER 79-21/01P

Mr. B. H. Grier, Director of Regulation
United States' Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

In accordance with Technical Specification 6.9.1.8.e, the following occurrence is reported. The report was discussed with Mr. D. A. Beckman at 1030 hours on July 26, 1979.

During testing of the Beaver Valley Emergency Bus 4160V/480 Volt General Electric transformers, megger readings have indicated a significant degradation of insulation resistance as compared to the original acceptance testing. Because of this degradation, all four transformers on the emergency busses will be replaced with properly qualified ITE transformers which are available on-site. This replacement will be completed prior to the plant returning to power.

Any additional information or corrective action will be included in the followup report.

Very truly yours,

HP Williams

for J. A. Werling
Superintendent

②
790801C440

422 256

A002
5/11

Mr. B. H. Grier
July 26, 1979
BVPS:JAW:693
Page 2

cc: Director Of Management & Program Analysis ✓
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. L. Wigginton, BVPS Licensing Project Manager
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. A. Beckman, Nuclear Regulatory Commission, King of Prussia, PA

G. A. Olson, Secretary, Prime Movers Committee - EEI