



MISSISSIPPI POWER & LIGHT COMPANY
Helping Build Mississippi
P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

PRODUCTION DEPARTMENT

June 18, 1979

79 JUN 22 9:17
USNRC REGION 3
ATLANTA, GEORGIA

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street - Suite 3100
Atlanta, Georgia 30303

ATTENTION: Mr. J. P. O'Reilly, Director

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
File 0270/L-860.0/15521
Evaluation of IE Bulletin 79-09
AECM-79/63

We have completed our review of IE Bulletin 79-09 entitled "Failure of G. E. Type AK-2 Circuit Breaker in Safety Related Systems." We have found that Grand Gulf Nuclear Station does utilize G. E. type AK-2 circuits breakers in the 125V D. C. system. However, these breakers do not have any undervoltage tripping devices and therefore, are not affected by the problems described in the Bulletin. Based on this finding, we are planning no further action in response to this bulletin.

Yours truly,

L. F. Dale
Nuclear Project Manager

RTE/pa

cc: Mr. N. L. tampley
Mr. R. B. McGehee
Mr. T. B. Conner

Mr. John G. Davis, Director
Division of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

498 294

7908090071

790136