

BEFORE THE

UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of

PHILADELPHIA ELECTRIC COMPANY

:
:
:

Docket No. 50-278

APPLICATION FOR AMENDMENT

OF

FACILITY OPERATING LICENSE

DPR-56

Edward G. Bauer, Jr.

Eugene J. Bradley

2301 Market Street

Philadelphia, Pennsylvania 19101

Attorneys for

Philadelphia Electric Company

7908060397

558203

BEFORE THE

UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of :
: Docket No. 50-278
PHILADELPHIA ELECTRIC COMPANY :

APPLICATION FOR AMENDMENT
OF
FACILITY OPERATING LICENSE
DPR-56

Philadelphia Electric Company, Licensee under Facility Operating License DPR-56 for Peach Bottom Atomic Power Station Unit No. 3, hereby requests that the Technical Specifications incorporated in Appendix A of the Operating License be amended by deleting pages 15a and 15b, by revising certain sections as indicated by a vertical bar in the margin of attached pages iv, v, 1, 3, 7, 10, 11, 14, 15, 18, 19, 20, 33, 35, 37, 40, 54, 73, 74, 108, 111, 115, 119, 120, 122, 133a, 133c, 138, 140, 140a, 140c, 140d, 140e, 144, 152a, 157, and 241, and by adding page 142g.

558204

The changes to the Technical Specifications are being requested to: 1) accommodate the third refueling of the Peach Bottom Unit 3 reactor, (2) identify the operating limits for all fuel types, including reload 3 pre-pressurized retrofit 8X8 fuel, for cycle 4 operation (3) modify the APRM and RBM setpoint equations, (4) delete the fuel densification power spiking penalty for 8X8 fuel (5) delete the reactor vessel pressure operating limit, (6) permit the continued use of the fast scram control rod drive during cycle 4, and (7) increase the Standby Liquid Control System capacity.

An analysis of the safety considerations involved in the reactor refueling and the cycle 4 operating limits for all fuel types are set forth in a document entitled "Supplemental Reload Licensing Submittal for Peach Bottom Atomic Power Station Unit 3 Reload 3, "NEDO-24204A, July, 1979 which is filed herewith and incorporated herein by reference.

The proposed amendment would permit the loading of the prepressurized retrofit 8X8 fuel design. A safety evaluation for use of the prepressurized retrofit 8X8 fuel, previously approved by the Nuclear Regulatory Commission is provided by General Electric document NEDE-24011-P-A, August, 1978

The Licensee proposes that Tables 1.1-1 and 1.1-2 (pages 15a, 15b) be deleted, and that the APRM and RBM setpoint equations shown on pages 10, 11, 37, and 73 be modified. Pages 15a and 15b contain fuel parameters that have been superceded by

558205

Tables 5-1 and 5-2 provided in document NEDE-24011-P-A, "General Electric Boiling Water Reactor Generic Reload Fuel Application", previously approved by the Nuclear Regulatory Commission and which is incorporated herein by reference. A safety evaluation covering the APRM and RBM setpoint equation modifications are provided in Section 3.5 of the Nuclear Regulatory Commission's Safety Evaluation Report supporting Amendments 35, 32 and 9 to License Numbers DPR-33, 52, and 68 for Browns Ferry Nuclear Plant Units 1, 2 and 3 respectively.

The safety analysis provided in NEDO-24204A includes the effects of densification power spiking on allowable linear heat generation rate (LHGR). This provides the bases for deleting the fuel densification power spiking penalty factor for all 8X8 fuel.

The amendment request proposes deletion of the maximum operating dome pressure limit of 1020 psig. The operating limit would therefore be limited by the reactor vessel high pressure scram setpoint of 1055 psig. The results of a sensitivity study performed by General Electric shows that the peak vessel pressure increase is only 13 psi (1301 psig to 1314 psig) for an increase in the assumed initial pressure from 1020 psig to 1055 psig. The design bases over pressure transient analysis provided in NEDO-24204A demonstrates a margin of 74 psi to the vessel code limit. This margin is far in excess of a possible 13 psi additional rise resulting from an initial dome pressure increase over 1020 psig. There is added conservatism by virtue of the fact that the trend

is for the resulting pressure peak increase to be much less than directly proportional to the increase in initial dome pressure.

NEDO-21363-2A, July 1979, filed herewith and incorporated herein by reference, provides the results of an evaluation of the fast scram control rod drive (FSCRD) which was operated in Peach Bottom Unit 3 during cycle 2 and subsequently disassembled and inspected. Based on the performance and inspection of this FSCRD, the safety evaluation presented in this report demonstrates that continued operation of the currently installed FSCRD, during cycle 4, does not introduce an unreviewed safety question and has no effect on parameters used in the safety analyses provided in NEDO-24204A.

The Technical Specification bases 3.4.A state that the Standby Liquid Control System (SLCS) has the capability of bringing the reactor 3.0% Δk subcritical. The reload licensing analysis for Peach Bottom 3 Reload 3 indicated that the SLCS with its present capability (600 ppm boron) would only bring the reactor 2.2% Δk subcritical. Therefore, the Licensee proposes increasing the SLCS capability from 600 ppm to 660 ppm boron. At this increased boron concentration, the safety analysis provided in NEDO-24204A demonstrates that the SLCS will bring the core to at least 3.2% Δk subcritical.

Additionally, the Licensee requests deletion of the last sentence on page 138 to eliminate an inconsistency resulting from approved amendment No. 41, May 17, 1978, that increased the allowable relief valve settings.


Since the proposed changes to the Technical Specifications do not involve a significant hazards consideration, pursuant to 10 CFR 170.22, Philadelphia Electric Company, for fee purposes, proposes that the Application for Amendment be considered a Class III Amendment.

The Plant Operation Review Committee and the Operation and Safety Review Committee have reviewed this proposed change to the Technical Specifications and have concluded that it does not involve an unreviewed safety question or a significant hazard consideration, and will not endanger the health and safety of the public.

Respectfully submitted,

PHILADELPHIA ELECTRIC COMPANY

By


Vice President

558208

COMMONWEALTH OF PENNSYLVANIA

:

SS.

COUNTY OF PHILADELPHIA


:

S. L. Daltroff, being first duly sworn, deposes and says:

That he is Vice President of Philadelphia Electric Company, the Applicant herein; that he has read the foregoing Application for Amendment of Facility Operating Licenses and knows the contents thereof; and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.



Subscribed and sworn to
before me this 31st day
of July, 1979




Notary Public

ELIZABETH H. BOYER
Notary Public, Phila., Phila. Co.
My Commission Expires Jan. 30, 1982

558209

CERTIFICATE OF SERVICE

I certify that service of the foregoing Application was made upon the Board of Supervisors, Peach Bottom Township, York County, Pennsylvania, by mailing a copy thereof, via first-class mail, to Albert R. Steele, Chairman of the Board of Supervisors, R. D. No. 1, Delta, Pennsylvania 17314; upon the Board of Supervisors, Fulton Township, Lancaster County, Pennsylvania, by mailing a copy thereof, via first-class mail, to George K. Brinton, Chairman of the Board of Supervisors, Peach Bottom, Pennsylvania 17563; and upon the Board of Supervisors, Drumore Township, Lancaster County, Pennsylvania, by mailing a copy thereof, via first-class mail, to Wilmer P. Bolton, Chairman of the Board of Supervisors, R. D. No. 1, Holtwood, Pennsylvania 17532; all this Second day of August, 1979.



Eugene J. Bradley

Attorney for
Philadelphia Electric Company

558210

LIST OF FIGURES

<u>Figure</u>	<u>Title</u>	<u>Page</u>
1.1-1	APRM Flow Bias Scram Relationship To Normal Operating Conditions	16
4.1.1	Instrument Test Interval Determination Curves	55
4.2.2	Probability of System Unavailability Vs. Test Interval	98
3.4.1	Required Volume and Concentration of Standby Liquid Control System Solution	122
3.4.2	Required Temperature vs. Concentration for Standby Liquid Control System Solution	123
3.5.1.A	MAPLHGR Vs. Planar Average Exposure, Unit 3, 7x7 Fuel, Type 3	142
3.5.1.B	MAPLHGR Vs. Planar Average Exposure, Unit 3, 7x7 Fuel, Type 2	142a
3.5.1.C	MAPLHGR Vs. Planar Average Exposure, Unit 3, 8x8 Fuel, Type H	142b
3.5.1.D	MAPLHGR Vs. Planar Average Exposure, Unit 3, 8x8 Fuel, Type L	142c
3.5.1.E	Kf Factor Vs. Core Flow	142d
3.5.1.F	MAPLHGR Vs. Planar Average Exposure, Unit 3, 8x8 PTA Fuel	142e
3.5.1.G	MAPLHGR Vs. Planar Average Exposure, Unit 3, 8x8R Fuel	142f
3.5.1.H	MAPLHGR Vs. Planar Average Exposure, Unit 3, P 8X8R Fuel	142g
3.6.1	Minimum Temperature for Pressure Tests such as required by Section XI	164
3.6.2	Minimum Temperature for Mechanical Heatup or Cooldown following Nuclear Shutdown	164a
3.6.3	Minimum Temperature for Core Operation (Criticality)	164b
3.6.4	Transition Temperature Shift vs. Fluence	164c
6.2-1	Management Organization Chart	244
6.2-2	Organization for Conduct of Plant Operation	245

8211

LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
3.1.1	Reactor Protection System (Scram) Instrumentation Requirement	37
4.1.1	Reactor Protection System (Scram) Instrument Functional Tests	41
4.1.2	Reactor Protection System (Scram) Instrument Calibration	44
3.2.A	Instrumentation That Initiates Primary Containment Isolation	61
3.2.B	Instrumentation That Initiates or Controls the Core and Containment Cooling Systems	64
3.2.C	Instrumentation That Initiates Control Rod Blocks	73
3.2.D	Radiation Monitoring Systems That Initiate and/or Isolates Systems	75
3.2.E	Instrumentation That Monitors Drywell Leak Detection	76
3.2.F	Surveillance Instrumentation	77
3.2.G	Instrumentation That Initiates Recirculation Pump Trip	79
4.2.A	Minimum Test and Calibration Frequency for PCIS	80

558212

1.0 DEFINITIONS

The succeeding frequently used terms are explicitly defined so that a uniform interpretation of the specifications may be achieved.

Alteration of the Reactor Core - The act of moving any component in the region above the core support plate, below the upper grid and within the shroud.

Normal control rod movement with the control drive hydraulic system is not defined as a core alteration. Normal movement of in-core instrumentation and the traversing in-core probe is not defined as a core alteration.

Channel - A channel is an arrangement of a sensor and associated components used to evaluate plant variables and produce discrete outputs used in logic. A channel terminates and loses its identity where individual channel outputs are combined in logic.

Cold Condition - Reactor coolant temperature equal to or less than 212°F.

Cold Shutdown - The reactor is in the shutdown mode, the reactor coolant temperature equal to or less than 212°F, and the reactor vessel is vented to atmosphere.

Critical Power Ratio (CPR) - The critical power ratio is the ratio of that assembly power which causes some point in the assembly to experience transition boiling to the assembly power at the reactor condition of interest as calculated by application of the GEXL correlation. (Reference NEDO-10958)

Engineered Safeguard - An engineered safeguard is a safety system the actions of which are essential to a safety action required in response to accidents.

Fraction of Limiting Power Density (FLPD) - The ratio of the linear heat generation rate (LHGR) existing at a given location to the design LHGR for that bundle type.

Functional Tests - A functional test is the manual operation or initiation of a system, subsystem, or component to verify that it functions within design tolerances (e.g., the manual start of a

558213

1.0 DEFINITIONS (Cont'd)

the automatic protective action at a level such that the safety limits will not be exceeded. The region between the safety limit and these settings represent margin with normal operation lying below these settings. The margin has been established so that with proper operation of the instrumentation the safety limits will never be exceeded.

Logic - A logic is an arrangement of relays, contacts and other components that produce a decision output.

- (a) Initiating - A logic that receives signals from channels and produces decision outputs to the actuation logic.
- (b) Actuation - A logic that receives signals (either from initiation logic or channels) and produces decision outputs to accomplish a protective action.

Logic System Functional Test - A logic system functional test means a test of all relays and contacts of a logic circuit to insure all components are operable per design intent. Where practicable, action will go to completion; i.e., pumps will be started and valves operated.

Maximum Fraction of Limiting Power Density (MFLPD) - The Maximum Fraction of Limiting Power Density (MFLPD) is the highest value existing in the core of the Fraction of Limiting Power Density (FLPD).

Minimum Critical Power Ratio (MCPR) - The minimum in-core critical power ratio corresponding to the most limiting fuel assembly in the core.

Mode of Operation - A reactor mode switch selects the proper interlocks for the operational status of the unit. The following are the modes and interlocks provided: Refuel Mode, Run Mode, Shutdown Mode, Startup/Hot Standby Mode.

Operable - A system or component shall be considered operable when it is capable of performing its intended function in its required manner.

558214

1.0 DEFINITIONS (Cont'd)

operable or are tripped, then they shall be performed prior to returning the system to an operable status.

Transition Boiling - Transition boiling means the boiling regime between nucleate and film boiling. Transition boiling is the regime in which both nucleate and film boiling occur intermittently with neither type being completely stable.

Trip System - A trip system means an arrangement of instrument channel trip signals and auxiliary equipment required to initiate action to accomplish a protective trip function. A trip system may require one or more instrument channel trip signals related to one or more plant parameters in order to initiate trip system action. Initiation or protective action may require the tripping of a single trip system or the coincident tripping of two trip systems.

558215

SAFETY LIMIT

LIMITING SAFETY SYSTEM SETTING

2.1.A (Cont'd)

In the event of operation with a maximum fraction of limiting power density (MFLPD) greater than the fraction of rated power (FRP), the setting shall be modified as follows:

$$S \leq (0.66 W + 54\%) \left(\frac{FRP}{MFLPD} \right)$$

where,

FRP = fraction of rated thermal power (3293 MWt)

MFLPD = maximum fraction of limiting power density where the limiting power density is 18.5 KW/ft for all 7X7 fuel and 13.4 KW/ft for all 8X8 fuel.

The ratio of FRP to MFLPD shall be set equal to 1.0 unless the actual operating value is less than the design value of 1.0, in which case the actual operating value will be used.

2. APRM--When the reactor mode switch is in the STARTUP position, the APRM scram shall be set at less than or equal to 15 percent of rated power.
3. IRM--The IRM scram shall be set at less than or equal to 120/125 of full scale.
4. When the reactor mode switch is in the STARTUP or RUN position, the reactor shall not be operated in the natural circulation flow mode.

558216

SAFETY LIMITB. Core Thermal Power Limit
(Reactor Pressure \leq 800 psia)

When the reactor pressure is \leq 800 psia or core flow is less than 10% of rated, the core thermal power shall not exceed 25% of rated thermal power.

C. Whenever the reactor is in the shutdown condition with irradiated fuel in the reactor vessel, the water level shall not be less than 17.1 in. above the top of the normal active fuel zone.

LIMITING SAFETY SYSTEM SETTINGB. APRM Rod Block Trip Setting

$$SRB \leq 0.66W + 42\%$$

where:

SRB = Rod block setting in percent of rated thermal power (3293 Mwt)

W = Loop recirculation flow rate in percent of rated (rated loop recirculation flow rate equals 34.2×10^6 lb/hr).

In the event of operation with a maximum fraction limiting power density (MFLPD) greater than the fraction of rated power (FRP), the setting shall be modified as follows:

$$SRB \leq (0.66 W + 42\%) \left(\frac{FRP}{MFLPD} \right)$$

where:

FRP = fraction of rated thermal power (3293 Mwt).

MFLPD = maximum fraction of limiting power density where the limiting power density is 18.5 KW/ft for all 7X7 fuel and 13.4 KW/ft for all 8X8 fuel

The ratio of FRP to MFLPD shall be set equal to 1.0 unless the actual operating value is less than the design value of 1.0, in which case the actual operating value will be used.

C. Scram and isolation-- \geq 538 in. above reactor low water level vessel zero (0" on level instruments)

558217

1.1.A BASES (Cont'd)

The required input to the statistical model are the uncertainties listed on Table 5-1 of Reference 3, the nominal values of the core parameters listed in Table 5-2 of Reference 3, and the relative assembly power distribution shown in Figure 5-1a of Reference 3.

The basis for the uncertainties in the core parameters are given in Reference 2 and the basis for the uncertainty in the GEXL correlation is given in Reference 1. The power distribution is based on a typical 764 assembly core in which the rod pattern was arbitrarily chosen to produce a skewed power distribution having the greatest number of assemblies at the highest power levels. The worst distribution in Peach Bottom Atomic Power Station Unit 3 during any fuel cycle would not be as severe as the distribution used in the analysis.

B. Core Thermal Power Limit (Reactor Pressure < 800 psia on Core Flow < 10% of Rated)

The use of the GEXL correlation is not valid for the critical power calculations at pressures below 800 psia or core flows less than 10% of rated. Therefore, the fuel cladding integrity safety limit is established by other means. This is done by establishing a limiting condition of core thermal power operation with the following basis.

Since the pressure drop in the bypass region is essentially all elevation head which is 4.56 psi the core pressure drop at low power and all flows will always be greater than 4.56 psi. Analyses show that with a flow of 28×10^3 lbs/hr bundle flow, bundle pressure drop is nearly independent of bundle power and has a value of 3.5 psi. Thus, the bundle flow with a 4.56 psi driving head will be greater than 28×10^3 lbs/hr irrespective of total core flow and independent of bundle power for the range of bundle powers of concern. Full scale ATLAS test data taken at pressures from 14.7 psia to 800 psia indicate that the fuel assembly critical power at this flow is approximately 3.35 MWt. With the design peaking factors this corresponds to a core thermal power of more than 50%. Therefore a core thermal power limit of 25% for reactor pressures below 800 psia or core flow less than 10% is conservative.

C. Power Transient

558218

Plant safety analyses have shown that the scrams caused by exceeding any safety setting will assure that the Safety Limit of Specification 1.1.A or 1.1.B will not be exceeded. Scram times are checked periodically to assure the insertion times are adequate. The thermal power transient resulting when a scram is accomplished other than by the expected scram signal (e.g., scram from neutron flux following closure of the main turbine stop valves) does not necessarily cause fuel damage.

1.1.C BASES (Cont'd.)

However, for this specification a Safety Limit violation will be assumed when a scram is only accomplished by means of a backup feature of the plant design. The concept of not approaching a Safety Limit, provided scram signals are operable, is supported by the extensive plant safety analysis.

The computer provided with Peach Bottom Unit 3 has a sequence annunciation program which will indicate the sequence in which events such as scram, APRM trip initiation, pressure scram initiation, etc. occur. This program also indicates when the scram setpoint is cleared. This will provide information on how long a scram condition exists and thus provide some measure of the energy added during a transient. Thus, computer information normally will be available for analyzing scrams; however, if the computer information should not be available for any scram analysis, Specification 1.1.C will be relied upon to determine if a Safety Limit has been violated.

D. Reactor Water Level (Shutdown Condition)

During periods when the reactor is shutdown, consideration must also be given to water level requirements due to the effect of decay heat. If reactor water level should drop below the top of the active fuel during this time, the ability to cool the core is reduced. This reduction in core cooling capability could lead to elevated cladding temperatures and clad perforation. The core can be cooled sufficiently should the water level be reduced to two-thirds the core height. Establishment of the safety limit at 17.7 inches above the top of the fuel provides adequate margin. This level will be continuously monitored.

E. References

1. General Electric BWR Thermal Analysis Basis (GETAB): Data, Correlation and Design Application, January 1977 (NEDO-10958-A).
2. Process Computer Performance Evaluation Accuracy, General Electric Company BWR Systems Department, June 1974 (NEDO-20340)
3. "General Electric Boiling Water Reactor Generic Reload Fuel Application", NEDE-24011-P-A.

558219

2.1 BASES (Cont'd.)

For analyses of the thermal consequences of the transients a MCPR equal to or greater than the operating limit MCPR given in Specification 3.5.K is conservatively assumed to exist prior to initiation of the limiting transients. This choice of using conservative values of controlling parameters and initiating transients at the design power level produces more pessimistic answers than would result by using expected values of control parameters and analyzing at higher power levels.

Steady state operation without forced recirculation will not be permitted. The analysis to support operation at various power and flow relationships has considered operation with either one or two recirculating pumps.

In summary:

- i. The abnormal operational transients were analyzed to a power level of 3440 MWt (104.5% rated power) to determine operating limit MCPR's.
- ii. The licensed maximum power level is 3293 MWt.
- iii. Analyses of transients employ adequately conservative values of the controlling reactor parameters.
- iv. The analytical procedures now used result in a more logical answer than the alternative method of assuming a higher starting power in conjunction with the expected values for the parameters.

The bases for individual trip settings are discussed in the following paragraphs.

A. Neutron Flux Scram

The Average Power Range Monitoring (APRM) system, which is calibrated using heat balance data taken during steady state conditions, reads in percent of rated thermal power (3293 MWt). Because fission chambers provide the basic input signals, the APRM system responds directly to average neutron flux. During transients, the instantaneous rate of heat transfer from the fuel (reactor thermal power) is less than the instantaneous neutron flux due to the time constant of the fuel. Therefore, during abnormal operational transients, the thermal power of the fuel will be less than that indicated by the neutron flux at the scram setting. Analyses demonstrate that with a 120 percent scram trip setting, none of the abnormal operational transients analyzed violate the fuel Safety Limit and there is a substantial margin from fuel damage. Therefore, the use of flow referenced scram trip provides even additional margin.

558220

2.1.A BASES (Cont'd.)

An increase in the APRM scram trip setting would decrease the margin present before the fuel cladding integrity Safety Limit is reached. The APRM scram trip setting was determined by an analysis of margins required to provide a reasonable range for maneuvering during operation. Reducing this operating margin would increase the frequency of spurious scrams which have an adverse effect on reactor safety because of the resulting thermal stresses. Thus, the APRM scram trip setting was selected because it provides adequate margin for the fuel cladding integrity Safety Limit yet allows operating margin that reduces the possibility of unnecessary scrams.

The scram trip setting must be adjusted to assure that the LHGR transient peak is not increased for any combination of maximum fraction of limiting power density (MFLPD) and reactor core thermal power. The scram setting is adjusted in accordance with the formula in Specification 2.1.A.1, when the MFLPD is greater than the fraction of rated power (FRP).

Analyses of the limiting transients show that no scram adjustment is required to assure MCPR greater than 1.07 when the transient is initiated from MCPR greater than the operating limit given in Specification 3.5.K.

For operation in the startup mode while the reactor is at low pressure, the APRM scram setting of 15 percent of rated power provides adequate thermal margin between the setpoint and the Safety Limit, 25 percent of rated. The margin is adequate to accommodate anticipated maneuvers associated with power plant startup. Effects of increasing pressure at zero or low void content are minor, cold water from sources available during startup is not much colder than that already in the system, temperature coefficients are small, and control rod patterns are constrained to be uniform by operating procedures backed up by the Rod Worth Minimizer and Rod Sequence Control System. Worth of individual rods is very low in a uniform rod pattern. Thus, of all possible sources of reactivity input, uniform control rod withdrawal is the most probable cause of significant power rise. Because the flux distribution associated with uniform rod withdrawals does not involve high local peaks, and because several rods must be moved to change power by a significant percentage of rated power, the rate of power is very slow. Generally, the heat flux is in near equilibrium with the fission rate. In an assumed uniform rod withdrawal approach to the scram level, the rate of power rise is no more than 5 percent of rated power per minute, and the APRM system would be more than adequate to assure a scram before the power could exceed the Safety Limit. The 15 percent APRM scram remains active until the mode switch is placed in the RUN position. This switch occurs when the reactor pressure is greater than 850 psig.

2.1.A EASES (Cont'd.)

The IRM system consists of 8 chambers, 4 in each of the reactor protection system logic channels. The IRM is a 5-decade instrument which covers the range of power level between that covered by the SRM and the APRM. The 5-decades are covered by the IRM by means of a range switch and the 5-decades are broken down into 10 ranges, each being one-half of a decade in size. The IRM scram trip setting of 120 divisions is active in each range of the IRM. For example, if the instrument were on range 1, the scram setting would be a 120 divisions for that range; likewise, if the instrument were on range 5, the scram would be 120 divisions on that range. Thus, as the IRM is ranged up to accommodate the increase in power level, the scram trip setting is also ranged up. The most significant sources of reactivity change during the power increase are due to control rod withdrawal. For in-sequence control rod withdrawal the rate of change of power is slow enough due to the physical limitation of withdrawing control rods, that heat flux is in equilibrium with the neutron flux and an IRM scram would result in a reactor shutdown well before any Safety Limit is exceeded.

In order to assure that the IRM provided adequate protection against the single rod withdrawal error, a range of rod withdrawal accidents was analyzed. This analysis included starting the accident at various power levels. The most severe case involves an initial condition in which the reactor is just subcritical and the IRM system is not yet on scale. This condition exists at quarter rod density. Additional conservatism was taken in this analyses by assuming that the IRM channel closest to the withdrawn rod is bypassed. The results of this analysis show that the reactor is scrammed and peak power limited to one percent of rated power, thus maintaining MCPR above 1.07. Based on the above analysis, the IRM provides protection against local control rod withdrawal errors and continuous withdrawal of control rods in-sequence and provides backup protection for the APRM.

B. APRM Rod Block Trip Setting

The APRM system provides a control rod block to avoid conditions which would result in an APRM scram trip if allowed to proceed. The APRM rod block trip setting, like the APRM scram trip setting, is automatically varied with recirculation loop flow rate. The flow variable APRM rod block trip setting provides margin to the APRM scram trip setting over the entire recirculation flow range. As with the APRM scram trip setting, the APRM rod block trip setting is adjusted if the maximum fraction of limiting power density exceeds the fraction of rated power, thus preserving the APRM rod block safety margin. As with the scram setting, this may be accomplished by adjusting the APRM gain.

2.2 BASES

REACTOR COOLANT SYSTEM INTEGRITY

The pressure relief system for each unit at the Peach Bottom Atomic Power Station has been sized to meet two design bases. First, the total capacity of the safety/relief valves and safety valves has been established to meet the overpressure protection criteria of the ASME Code. Second, the distribution of this required capacity between safety valves and relief valves has been set to meet design basis 4.4.4.1 of subsection 4.4 of the FSAR which states that the nuclear system safety/relief valves shall prevent opening of the safety valves during normal plant isolations and load rejections.

The details of the analysis which shows compliance with the ASME Code requirements are presented in subsection 4.4 of the FSAR and the Reactor Vessel Overpressure Protection Summary Technical Report submitted in Appendix K.

Eleven safety/relief valves and two safety valves have been installed on Peach Bottom Unit 3. The analysis of the worst overpressure transient, (3-second closure of all main steamline isolation valves) neglecting the direct scram (valve position scram) results in a maximum vessel pressure of 1301 psig if a neutron flux scram is assumed. This results in a 74 psig margin to the code allowable overpressure limit of 1375 psig.

The analysis of the plant isolation transient (Load Rejection with bypass valve failure to open) assuming a turbine trip scram is presented in NEDO-24204A for Peach Bottom Unit 3. This analysis shows that the 11 safety/relief valves limit pressure at the safety valves to 25 psi below the setting of the safety valves. Therefore, the safety valves will not open.

The safety/relief valve settings satisfy the Code requirements that the lowest valve set point be at or below the vessel design pressure of 1250 psig. These settings are also sufficiently above the normal operating pressure range to prevent unnecessary cycling caused by minor transients.

The results of postulated transients where inherent safety/relief valve actuation is required are given in Section 14.0 of the Final Safety Analysis Report.

The design pressure of the shutdown cooling piping of the Residual Heat Removal System is not exceeded with the reactor vessel steam dome less than 75 psig.

558223

LIMITING CONDITIONS FOR OPERATIONSURVEILLANCE REQUIREMENTS3.1 REACTOR PROTECTION SYSTEMApplicability:

Applies to the instrumentation and associated devices which initiate a reactor scram.

Objective:

To assure the operability of the reactor protection system.

Specification:

The setpoint, minimum number of trip systems, and minimum number of instrument channels that must be operable for each position of the reactor mode switch shall be as given in Table 3.1.1. The designed system response times from the opening of the sensor contact up to and including the opening of the trip actuator contacts shall not exceed 100 milli-seconds

3.1 REACTOR PROTECTION SYSTEMApplicability:

Applies to the surveillance of the instrumentation and associated devices which initiate reactor scram.

Objective:

To specify the type and frequency of surveillance to be applied to the protection instrumentation.

Specification:

- A. Instrumentation systems shall be functionally tested and calibrated as indicated in Tables 4.1.1 and 4.1.2 respectively.
- B. Daily during reactor power operation, the maximum fraction of limiting power density shall be checked and the SCA and APRM Rod Block settings given by equations in Specification 2.1.A.1 and 2.1.B shall be calculated if maximum fraction of limiting power density exceeds the fraction of rated power.

558224

TABLE 3.1.1

REACTOR PROTECTION SYSTEM (SCRAM) INSTRUMENTATION REQUIREMENT

Minimum No. of Operable Instrument Channels per Trip System (1)	Trip Function	Trip Level Setting	Modes in Which Function Must be Operable			Number of Instrument Channels Provided by Design	Action (1)
			Refuel (7)	Startup	Run		
1	Mode Switch In Shutdown		X	X	X	1 Mode Switch (4 Sections)	A
1	Manual Scram		X	X	X	2 Instrument Channels	A
3	IRM High Flux	$\leq 120/125$ of Full Scale	X	X	(5)	8 Instrument Channels	A
3	IRM Inoperative		X	X	(5)	8 Instrument Channels	A
2	APRM High Flux	$(.66W+54)$ FRP/MFLPD (12) (13)			X	6 Instrument Channels	A or B
2	APRM Inoperative	(11)	X	X	X	6 Instrument Channels	A or B
2	APRM Downscale	≥ 2.5 Indicated on Scale			(10)	6 Instrument Channels	A or B
2	APRM High Flux in Startup	$\leq 15\%$ Power	X	X		6 Instrument Channels	A
2	High Reactor Pressure	≤ 1055 psig	X(9)	X	X	4 Instrument Channels	A
2	High Drywell Pressure	≤ 2 psig	X(8)	X(8)	X	4 Instrument Channels	A
2	Reactor Low Water Level	≥ 0 in. Indicated Level	X	X	X	4 Instrument Channels	A

558225

NOTES FOR TABLE 3.1.1 (Cont'd)

10. The APRM downscale trip is automatically bypassed when the IRM instrumentation is operable and not high.
11. An APRM will be considered operable if there are at least 2 LPRM inputs per level and at least 14 LPRM inputs of the normal complement.
12. This equation will be used in the event of operation with a maximum fraction of limiting power density (MFLPD) greater than the fraction of rated power (FRP), where:

FRP = fraction of rated thermal
power (3293MWt).

MFLPD = maximum fraction of limiting
power density where the
limiting power density is
18.5 KW/ft for all 7x7 fuel
and 13.4 KW/ft for all 8x8
fuel.

The ratio of FRP to MFLPD shall be set equal to 1.0 unless the actual operating value is less than the design value of 1.0, in which case the actual operating value will be used.

W = Loop Recirculation flow in percent of
design. W is 100 for core flow of
102.5 million lb/hr or greater.

Trip level setting is in percent of rated power (3293 MWt).

13. See Section 2.1.A.1.

558226

4.1 BASES (Cont'd)

Experience with passive type instruments in generating stations and substations indicates that the specified calibrations are adequate. For those devices which employ amplifiers, etc., drift specifications call for drift to be less than 0.4% month; i.e., in the period of a month a maximum drift of 0.4% could occur, thus providing for adequate margin.

For the APRM systems, drift of electronic apparatus is not the only consideration in determining a calibration frequency. Change in power distribution and loss of chamber sensitivity dictate a calibration every seven days. Calibration on this frequency assures plant operation at or below thermal limits.

A comparison of Tables 4.1.2 and 4.1.3 indicates that two instrument channels have not been included in the latter tables. These are: mode switch in shutdown and manual scram. All of the devices or sensors associated with these scram functions are simple on-off switches, and, hence, calibration during operation is not applicable.

- B. The MFLPD is checked once per day to determine if the APRM scram requires adjustment. Only a small number of control rods are moved daily and thus the MFLPD is not expected to change significantly. Therefore, a daily check of the MFLPD is adequate.

The sensitivity of LPRM detectors decreases with exposure to neutron flux at a slow and approximately constant rate. This is compensated for in the APRM system by calibrating twice a week using heat balance data and by calibrating individual LPRM's every 6 weeks, using TIP traverse data.

558227

TABLE 3.2.C

INSTRUMENTATION THAT INITIATES CONTROL ROD BLOCKS

Minimum No. Of Operable Instrument Channels Per Trip System	Instrument	Trip Level Setting	Number of Instrument Channels Provided by Design	Action
2	APRM Upscale (Flow Biased)	$\leq (0.66W+42) \times \frac{FRP}{MFLPD}$ (2)	6 Inst. Channels	(1)
2	APRM Upscale (Startup Mode)	$\leq 12\%$	6 Inst. Channels	(1)
2	APRM Downscale	≥ 2.5 indicated on scale	6 Inst. Channels	(1)
1 (7)	Rod Block Monitor (Flow Biased)	$\leq (0.66W+41) \times \frac{FRP}{MFLPD}$ (2)	2 Inst. Channels	(1)
1 (7)	Rod Block Monitor Downscale	≥ 2.5 indicated on scale	2 Inst. Channels	(1)
3	IRM Downscale (3)	≥ 2.5 indicated on scale	8 Inst. Channels	(1)
3	IRM Detector not in Startup Position	(8)	8 Inst. Channels	(1)
3	IRM Upscale	$\leq 10^8$ indicated on scale	8 Inst. Channels	(1)
2 (5)	SRM Detector not in Startup Position	(4)	4 Inst. Channels	(1)
2 (5) (6)	SRM Upscale	$\leq 10^5$ counts/sec.	4 Inst. Channels	(1)

POOR ORIGINAL

Amendment No.

558228

NOTES FOR TABLE 3.2.C

1. For the startup and run positions of the Reactor Mode Selector Switch, there shall be two operable or tripped trip systems for each function. The SRM and IRM blocks need not be operable in "Run" mode, and the APRM and RBM rod blocks need not be operable in "Startup" mode. If the first column cannot be met for one of the two trip systems, this condition may exist for up to seven days provided that during that time the operable system is functionally tested immediately and daily thereafter; if this condition lasts longer than seven days, the system shall be tripped. If the first column cannot be met for both trip systems, the systems shall be tripped.

2. This equation will be used in the event of operation with a maximum fraction of limiting power density (MFLPD) greater than the fraction of rated power (FRP) where:

FRP = fraction of rated thermal power (3293 MWt)

MFLPD = maximum fraction of limiting power density where the limiting power density is 18.5 KW/ft for all 7x7 fuel and 13.4 KW/ft for all 8x8 fuel.

The ratio of FRP to MFLPD shall be set equal to 1.0 unless the actual operating value is less than the design value of 1.0, in which case the actual operating value will be used.

W = Loop Recirculation flow in percent of design.

W is 100 for core flow of 102.5 million lb/hr or greater

Trip level setting is in percent of rated power (3293 MWt).

3. IRM downscale is bypassed when it is on its lowest range.
4. This function is bypassed when the count rate is ≥ 100 cps.
5. One of the four SRM inputs may be bypassed.
6. This SRM function is bypassed when the IRM range switches are on range 8 or above.
7. The trip is bypassed when the reactor power is $\leq 30\%$.
8. This function is bypassed when the mode switch is placed in Run.

558229

3.3 and 4.3 BASES (Cont'd.)B. Control Rods

1. Control rod dropout accidents as discussed in the FSAR can lead to significant core damage. If coupling integrity is maintained, the possibility of a rod dropout accident is eliminated. The overtravel position feature provides a positive check as only uncoupled drives may reach this position. Neutron instrumentation response to rod movement provides a verification that the rod is following its drive. Absence of such response to drive movement could indicate an uncoupled condition. Rod position indication is required for proper function of the rod sequence control system and the rod worth minimizer (RWM).
2. The control rod housing support restricts the outward movement of a control rod to less than 3 inches in the extremely remote event of a housing failure. The amount of reactivity which could be added by this small amount of rod withdrawal, which is less than a normal single withdrawal increment, will not contribute to any damage to the primary coolant system. The design basis is given in subsection 3.5.2 of the FSAR and the safety evaluation is given in subsection 3.5.4. This support is not required if the reactor coolant system is at atmospheric pressure since there would then be no driving force to rapidly eject a drive housing. Additionally, the support is not required if all control rods are fully inserted and if an adequate shutdown margin with one control rod withdrawn has been demonstrated, since the reactor would remain subcritical even in the event of complete ejection of the strongest control rod.
3. The Rod Worth Minimizer (RWM) and sequence mode of the Rod Sequence Control System (RSCS) restrict withdrawals and insertions of control rods to prespecified sequences. The group notch mode of the RSCS restricts movement of rods assigned to each notch group to notch withdrawal and insertion. All patterns associated with these restrictions have the characteristic that, assuming the worst single deviation from the restrictions, the drop of any control rod from the fully inserted position to the position of the control rod drive would not cause the reactor to sustain a power excursion resulting in the peak enthalpy of any pellet exceeding 280 calories per gram. An enthalpy of 280 calories per gram is well below the level at which rapid fuel dispersal could occur (i.e., 425 calories per gram). Primary system damage in this accident is not possible unless a significant amount of fuel is rapidly dispersed. Ref. Sections 3.6.6, 14.6.2 and 7.16.3.3 of the FSAR, NEDC-10527 and supplements thereto, and NEDE-24011-P-A.

558230

3.3 and 4.3 BASES (Cont'd)C. Scram Insertion Times

The control rod system is designed to bring the reactor subcritical at a rate fast enough to prevent fuel damage; i.e., to prevent the MCPR from becoming less than 1.07. Analysis of the limiting power transients shows that the negative reactivity rates resulting from the scram (Ref. NEDO-24204A) with the average response of all drives as given in the above Specification, provide the required protection, and the MCPR remains greater than 1.07.

The numerical values assigned to the specified scram performance are based on the analysis of data from other BWR's with control rod drives the same as those on Peach Bottom.

The occurrence of scram times within the limits, but significantly longer than the average, should be viewed as an indication of a systematic problem with control rod drives especially if the number of drives exhibiting such scram times exceeds one control rod of a (5x5) twenty-five control array.

In the analytical treatment of the transients, 390 milliseconds are allowed between a neutron sensor reaching the scram point and the start of negative reactivity insertion. This is adequate and conservative when compared to the typically observed time delay of about 270 milliseconds. Approximately 70 milliseconds after neutron flux reaches the trip point, the pilot scram valve solenoid power supply voltage goes to zero and approximately 200 milliseconds later, control rod motion begins. The 200 milliseconds are included in the allowable scram insertion times specified in Specification 3.3.C. In addition the control rod drop accident has been analyzed in NEDO-10527 and its supplements 1 & 2 for the scram times given in Specification 3.3.C.

Surveillance requirement 4.3.C was originally written and used as a diagnostic surveillance technique during pre-operational and startup testing of Dresden 2 & 3 for the early discovery and identification of significant changes in drive scram performance following major changes in plant operation. The reason for the application of this surveillance was the unpredictable and degraded scram performance of drives at Dresden 2. The cause of the slower scram performances has been conclusively

558231

3.4 STANDBY LIQUID CONTROL SYSTEM

Applicability:

Applies to the operating status of the Standby Liquid Control System

Objective

To assure the availability of a system with the capability to shut down the reactor and maintain the shutdown condition without the use of control rods.

Specification

A. Normal System Availability

1. During periods when fuel is in the reactor and prior to startup from a Cold Condition, the Standby Liquid Control System shall be operable, except as specified in 3.4.B below. This system need not be operable when the reactor is in the Cold Condition and all control rods are fully inserted and Specification 3.3.A is met.

4.4 STANDBY LIQUID CONTROL SYSTEM

Applicability:

Applies to the surveillance requirements of the Standby Liquid Control System

Objective

To verify the operability of the Standby Liquid Control System.

Specification

A. Normal System Availabilit

The operability of the Standby Liquid Control System the performance of the following tests:

1. At least once per month each pump loop shall be functionally tested by recirculating demineralized water to the test tank.
2. At least once during each operating cycle:
 - a. Check that the setting of the system relief valves is $1400 < P < 1680$ psig.
 - b. Manually initiate the system, except explosive valves. Pump boron solution through the recirculation path and back to the Standby Liquid Control Solution Tank. Minimum pump flow rate of 43 gpm against a system head of 1225 psig shall be verified. After pumping boron solution the system will be flushed and demineralized water.

558232

3.4 BASESSTANDBY LIQUID CONTROL SYSTEM

- A. The conditions under which the Standby Liquid Control System must provide shutdown capability are identified via the Plant Nuclear Safety Operational Analysis (Appendix G). If no more than one operable control rod is withdrawn, the basic shutdown reactivity requirement for the core is satisfied and the Standby Liquid Control system is not required. Thus, the basic reactivity requirement for the core is the primary determinant of when the liquid control system is required.

The purpose of the liquid control system is to provide the capability of bringing the reactor from full power to a cold, xenon-free shutdown condition assuming that none of the withdrawn control rods can be inserted. To meet this objective, the liquid control system is designed to inject a quantity of boron that produces a concentration of 660 ppm of boron in the reactor core in less than 125 minutes. The 660 ppm concentration in the reactor core will bring the reactor from full power to at least a $3.0\% \Delta k$ subcritical condition, considering the hot to cold reactivity difference, xenon poisoning, etc. The time requirement for inserting the boron solution was selected to override the rate of reactivity insertion caused by cooldown of the reactor following the xenon poison peak.

The minimum limitation on the relief valve setting is intended to prevent the recycling of liquid control solution via the lifting of a relief valve at too low a pressure. The upper limit on the relief valve settings provides system protection from overpressure.

- B. Only one of the two standby liquid control pumping loops is needed for operating the system. One inoperable pumping circuit does not immediately threaten shutdown capability, and reactor operation can continue while the circuit is being repaired. Assurance that the remaining system will perform its intended function and that the long term average availability of the system is not reduced is obtained for a one out of two system by an allowable equipment out of service time of one third of the normal surveillance frequency. This method determines an equipment out of service time of ten days. Additional conservatism is introduced by reducing the allowable out of service time to seven days, and by increased testing of the operable redundant component.

558233

3.4 BASES (Cont'd.)

- C. Level indication and alarm indicate whether the solution volume has changed, which might indicate a possible solution concentration change. The test interval has been established in consideration of these factors. Temperature and liquid level alarms for the system are annunciated in the control room.

The solution is kept at least 10°F above the saturation temperature to guard against boron precipitation. The margin is included in Figure 3.4.2.


The volume versus concentration requirement of the solution is such that, should evaporation occur from any point within the curve, a low level alarm will annunciate before the temperature versus concentration requirements are exceeded.

The quantity of stored boron includes an additional margin (25 percent) beyond the amount needed to shut down the reactor to allow for possible imperfect mixing of the chemical solution in the reactor water.

A minimum quantity of 3080 gallons of solution having a 19.3 percent sodium pentaborate concentration, or the equivalent as shown in Figure 3.4.1, is required to meet this shutdown requirement. The minimum required pumping rate of 43 gpm is based on the injection of the maximum volume permitted in Figure 3.4.1 in less than 125 minutes.

558234

WEIGHT PERCENT OF SODIUM PENTABORATE IN SOLUTION



NET VOLUME OF SOLUTION IN TANK (gal.)

558235

POOR ORIGINAL

Figure 3.4.1

LIMITING CONDITIONS FOR OPERATIONSURVEILLANCE REQUIREMENTS3.5.I Average Planar LHGR

During power operation, the APLHGR for each type of fuel as a function of average planar exposure shall not exceed the limiting value shown in Figure 3.5.1.A, B, C, D, F, G & H as applicable. If at any time during operation it is determined by normal surveillance that the limiting value of APLHGR is being exceeded, action shall be initiated within one (1) hour to restore APLHGR to within prescribed limits. If the APLHGR is not returned to within prescribed limits within five (5) hours reactor power shall be decreased at a rate which would bring the reactor to the cold shutdown condition within 36 hours unless APLHGR is returned to within limits during this period. Surveillance and corresponding action shall continue until reactor operation is within the prescribed limits.

3.5.J Local LHGR

During power operation, the linear heat generation rate (LHGR) of any rod in any fuel assembly at any axial location shall not exceed the maximum allowable LHGR as calculated by the following equation:

$$LHGR \leq LHGR_d [1 - (\Delta P/P)_{\max} (L/LT)]$$

$LHGR_d$ = Design LHGR

= 18.5 kW/ft for 7x7 fuel

13.4 kW/ft for all 8x8 fuel

$(\Delta P/P)_{\max}$ = Maximum power

spiking penalty

= 0.026 for 7x7 fuel

= 0.000 for 8x8 fuel

LT = Total core length

= 12.167 ft for 7x7 & 8x8 fuel

= 12.5 ft for 8x8R, 8x8 PTA and P 8x8R fuel

L = Axial position above bottom of core

4.5.I Average Planar LHGR

The APLHGR for each type of fuel as a function of average planar exposure shall be checked daily during reactor operation at $\geq 25\%$ rated thermal power.

4.5.J Local LHGR

The LHGR as a function of core height shall be checked daily during reactor operation at $\geq 25\%$ rated thermal power.

558236

Table 3.5-2

OPERATING LIMIT MCPR VALUES AS DETERMINED FROM
INDICATED TRANSIENTS FOR VARIOUS CORE EXPOSURES

<u>Fuel Type</u>	<u>MCPR Operating Limit For Incremental Cycle 4 Core Average Exposure</u>	
	<u>BOC to 2000 MWD/t Before EOC</u>	<u>2000 MWD/t before EOC To EOC</u>
7x7	1.23 (LH)	1.23 (LR)
8x8	1.24 (LH)	1.30 (LR)
PTA & P 8X8R	1.27 (RWE)	1.32 (LR)
8x8R	1.27 (RWE)	1.30 (LR)

RWE - Rod Withdrawal Error

LR - Load Rejection with failure of bypass valves to open

LH - Loss of 100°F Feedwater Heating

558237

3.5 BASES (Cont'd).

The HPCI and RCIC as well as all other Core Standby Cooling Systems must be operable when starting up from a Cold Condition. It is realized that the HPCI is not designed to operate until reactor pressure exceeds 150 psig and is automatically isolated before the reactor pressure decreases below 100 psig. It is the intent of this specification to assure that when the reactor is being started up from a Cold Condition, the HPCI is not known to be inoperable.

D. RCIC System

The RCIC is designed to provide makeup to the nuclear system as part of the planned operation for periods when the main condenser is unavailable. The nuclear safety analysis, FSAR Appendix G, shows that RCIC also services for decay heat removal when feed water is lost. In all other postulated accidents and transients, the ADS provides redundancy for the HPCI. Based on this and judgements on the reliability of the HPCI system, an allowable repair time of 1 month is specified. Immediate and weekly demonstrations of HPCI operability during RCIC outage is considered adequate based on judgement and practicality.

E. Automatic Depressurization System (ADS)

The limiting conditions for operating the ADS are derived from the Station Nuclear Operational Analysis (Appendix G) and a detailed functional analysis of the ADS (Section 6).

This specification ensures the operability of the ADS under all conditions for which the automatic or manual depressurization of the nuclear system is an essential response to station abnormalities.

The nuclear system pressure relief system provides automatic nuclear system depressurization for small breaks in the nuclear system so that the low pressure coolant injection (LPCI) and the core spray subsystems can operate to protect the fuel barrier.

Because the Automatic Depressurization System does not provide makeup to the reactor primary vessel, no credit is taken for the steam cooling of the core caused by the system actuation to provide further conservatism to the CSCS. Performance analysis of the Automatic Depressurization System is considered only with respect to its depressurizing effect in conjunction with LPCI or Core Spray and is based on 4 valves. There are five valves provided.

558238

3.5 BASES (Cont'd.)

H. Engineering Safeguards Compartments Cooling and Ventilation

One unit cooler in each pump compartment is capable of providing adequate ventilation flow and cooling. Engineering analyses indicate that the temperature rise in safeguards compartments without adequate ventilation flow or cooling is such that continued operation of the safeguards equipment or associated auxiliary equipment cannot be assured. Ventilation associated with the High Pressure Service Water Pumps is also associated with the Emergency Service Water pumps, and is specified in Specification 3.9.

I. Average Planar LHGR

This specification assures that the peak cladding temperature following the postulated design basis loss-of-coolant accident will not exceed the limit specified in the 10 CFR Part 50, Appendix K.

The peak cladding temperature (PCT) following a postulated loss-of-coolant accident is primarily a function of the average heat generation rate of all the rods of a fuel assembly at any axial location and is only dependent, secondarily on the rod to rod power distribution within an assembly. The peak clad temperature is calculated assuming a LHGR for the highest powered rod which is equal to or less than the design LHGR. This LHGR times 1.02 is used in the heat-up code along with the exposure dependent steady state gap conductance and rod-to-rod local peaking factors. The Technical Specification APLHGR is this LHGR of the highest powered rod divided by its local peaking factor. The limiting value for APLHGR is shown in Figure 3.5.1.A, B, C, D, F, G, and H.

The calculational procedure used to establish the APLHGR shown on Figures 3.5.1.A, B, C, D, F, G, and H is based on a loss-of-coolant accident analysis. The analysis was performed using General Electric (GE) calculational models which are consistent with the requirements of Appendix K to 10 CFR Part 50. A complete discussion of each code employed in the analysis is presented in Reference 4. Input and model changes in the Peach Bottom loss-of-coolant analysis which are different from the previous analyses performed with Reference 4 are described in detail in Reference 8. These changes to the analysis include: (1) consideration of the counter current flow limiting (CCFL) effect, (2) corrected code inputs, and (3) the effect of drilling alternate flow paths in the bundle lower tie plate.

558239

3.5.I BASES (Cont'd.)

A list of the significant plant parameters to the loss-of-coolant accident analysis is presented in Table 3.5-1.

J. Local LHGR

This specification assures that the linear heat generation rate in any 7X7 fuel rod is less than the design linear heat generation if fuel pellet densification is postulated. The power spike penalty specified is based on the analysis presented in Section 3.2.1 of Reference 1 and References 2 and 3, and assumes a linearly increasing variation in axial gaps between core bottom and top, and assures with a 95% confidence, that no more than one fuel rod exceeds the design linear heat generation rate due to power spiking. The LHGR as a function of core height shall be checked daily during reactor operation at $\geq 25\%$ power to determine if fuel burnup, or control rod movement has caused changes in power distribution. For LHGR to be a limiting value below 25% rated thermal power, the MTPF would have to be greater than 10 which is precluded by a considerable margin when employing any permissible control rod pattern. The densification power spiking penalty for the 8X8 fuel types is applied to the calculated LHGR's for the fuel loading error accident and the rod withdrawal error event in reference 6.

K. Minimum Critical Power Ratio (MCPR)

Operating Limit MCPR

The required operating limit MCPR's at steady state operating conditions as specified in Specification 3.5.K are derived from the established fuel cladding integrity Safety Limit MCPR of 1.07, and analyses of the abnormal operational transients presented in References 6 and 7. For any abnormal operating transient analysis evaluation with the initial condition of the reactor being at the steady state operating limit it is required that the resulting MCPR does not decrease below the Safety Limit MCPR at any time during the transient assuming instrument trip setting given in Specification 2.1.

To assure that the fuel cladding integrity Safety Limit is not exceeded during any anticipated abnormal operational transient, the most limiting transients have been analyzed to determine which result in the largest reduction in critical power ratio (CPR). The type of transients evaluated were loss of flow, increase in pressure and power, positive reactivity insertion, and coolant temperature decrease.

558240

3.5.K BASES (Cont'd.)

A brief summary of the analytical method used to determine the nuclear characteristics is given in Section 3 of Reference 7.

Analysis of the abnormal operational transients is presented in Section 5.2 of Reference 7. Input data and operating conditions used in this analysis are shown in Table 5-8 of Reference 7 and Section 7 of Reference 6.

L. Average Planar LHGR (APLHGR), Local LHGR, and Minimum Critical Power Ratio (MCPR)

In the event that the calculated value of APLHGR, LHGR or MCPR exceeds its limiting value, a determination is made to ascertain the cause and initiate corrective action to restore the value to within prescribed limits. The status of all indicated limiting fuel bundles is reviewed as well as input data associated with the limiting values such as power distribution, instrumentation data (Traversing In-core Probe-TIP, Local Power Range Monitor - LPRM, and reactor heat balance instrumentation), control rod configuration, etc., in order to determine whether the calculated values are valid.

In the event that the review indicates that the calculated value exceeding limits is valid, corrective action is immediately undertaken to restore the value to within prescribed limits. Following corrective action, which may involve alterations to the control rod configuration and consequently changes to the core power distribution, revised instrumentation data, including changes to the relative neutron flux distribution for up to 43 incore locations is obtained and the power distribution, APLHGR, LHGR and MCPR calculated. Corrective action is initiated within one hour of an indicated value exceeding limits and verification that the indicated value is within prescribed limits is obtained within five hours of the initial indication.

In the event that the calculated value of APLHGR, LHGR or MCPR exceeding its limiting value is not valid, i.e., due to an erroneous instrumentation indication etc., corrective action is initiated within one hour of an indicated value exceeding limits. Verification that the indicated value is within prescribed limits is obtained within five hours of the initial indication. Such an invalid indication would not be a violation of the limiting condition for operation and therefore would not constitute a reportable occurrence.

--8241

3.5.L BASES (Cont'd.)

Operating experience has demonstrated that a calculated value of APLHGR, LHGR or MCPR exceeding its limiting value predominately occurs due to this latter cause. This experience coupled with the extremely unlikely occurrence of concurrent operation exceeding APLHGR, LHGR or MCPR and a Loss of Coolant Accident or applicable Abnormal Operational Transients demonstrates that the times required to initiate corrective action (1 hour) and restore the calculated value of APLHGR, LHGR or MCPR to within prescribed limits (5 hours) are adequate.

3.5.M. References

1. "Fuel Densification Effects on General Electric Boiling Water Reactor Fuel", Supplements 6, 7, and 8 NEDM-10735, August 1973.
2. Supplement 1 to Technical Report on Densifications of General Electric Reactor Fuels, December 14, 1974 (Regulatory Staff).
3. Communication: V. A. Moore to I. S. Mitchell, "Modified GE Model for Fuel Densification", Docket 50-321, March 27, 1974.
4. General Electric Company Analytical Model for Loss-of-Coolant Analysis in Accordance with 10 CFR 50, Appendix K, NEDE-20566 (Draft), August 1974.
5. General Electric Refill Reflood Calculation (Supplement to SAFE Code Description) transmitted to the USAEC by letter, G. L. Gyorey to Victor Stello, Jr., dated December 20, 1974.
6. Supplemental Reload Licensing Submittal For Peach Bottom Atomic Power Station Unit 3 Reload No. 3, NEDO-24204A, July, 1979.
7. General Electric Boiling Water Reactor Generic Reload Fuel Application. NEDO-24011-P-A.
8. Loss-of-Coolant Accident Analysis For Peach Bottom Atomic Power Station Unit 3, NEDO-24082, December 1977.

558242

TABLE 3.5-1

SIGNIFICANT INPUT PARAMETERS TO THE
LOSS-CF-COOLANT ACCIDENT ANALYSIS

PLANT PARAMETERS:

Core Thermal Power	3440 MWt which corresponds to 105% of rated steam flow
Vessel Steam Output	14.05×10^6 lbm/h which corresponds to 105% of rated steam flow
Vessel Steam Dome Pressure	1055 psia
Recirculation Line Break Area For Large Breaks -	
Discharge	1.9 ft ² (DEA)
Suction	4.1 ft ²
Assumed Number of Drilled Bundles	432

FUEL PARAMETERS:

<u>Fuel Type</u>	<u>Fuel Bundle Geometry</u>	<u>Peak Technical Specification Design Linear Heat Axial Generation Rate</u>		<u>Initial</u>	<u>Ratio</u>
		<u>(KW/ft)</u>		<u>Minimum Critical Peaking Power Factor</u>	
7x7, Type 2	7 x 7	18.5	1.5	1.2	
7x7, Type 3	7 x 7	18.5	1.5	1.2	
8x8, Type H	8 x 8	13.4	1.4	1.2	
8x8, Type L	8 x 8	13.4	1.4	1.2	
8x8 PTA	8 x 8	13.4	1.4	1.2	
8x8R	8 x 8	13.4	1.4	1.2	
P 8x8R Type H	8 x 8	13.4	1.4	1.2	

558243

A more detailed list of input to each model and its source is presented in Section II of Reference 5.

PEACH BOTTOM UNIT 3

P8X8R FUEL

POOR ORIGINAL

Maximum Average Planar Linear
Heat Generation Rate (KW/FT)

558244




Figure 3.5.1.H Maximum Average Planar Linear Heat Generation Rate
Versus Planar Average Exposure

3.6.A Thermal and Pressurization
Limitations (Cont'd)

3. The reactor vessel head bolting studs shall not be under tension unless the temperature of the vessel head flange and the head is greater than 100°F.
4. The pump in an idle recirculation loop shall not be started unless the temperatures of the coolant within the idle and operating recirculation loops are within 50°F of each other.
5. The reactor recirculation pumps shall not be started unless the coolant temperatures between the dome and the bottom head drain are within 145°F.

4.6.A. Thermal and Pressurization
Limitations (Cont'd)

Selected neutron flux specimens shall be removed during the third refueling outage and tested to experimentally verify or adjust the calculated values of integrated neutron flux that are used to determine the NDTT for Figure 3.6.1

3. When the reactor vessel head bolting studs are tensioned and the reactor is in a Cold Condition, the reactor vessel shall temperature immediately below the head flange shall be permanently recorded.
4. Prior to and during startup of an idle recirculation loop, the temperature of the reactor coolant in the operating and idle loops shall be permanently logged.
5. Prior to starting a recirculation pump, the reactor coolant temperatures in the dome and in the bottom head drain shall be compared and permanently logged.

558245

3.6.A & 4.6.A. Bases (Cont'd)

The vessel pressurization temperatures at any time period can be determined from the thermal power output of the plant and its relation to the neutron fluence and from Figure 3.6.1, 3.6.2, or 3.6.3 in conjunction with Figure 3.6.4. Note: Figure 3.6.3 includes an additional 40°F margin required by 10 CFR 50 Appendix G.

Neutron flux wires and samples of vessel material are installed in the reactor vessel adjacent to the vessel wall at the core midplane level. The wires and samples will be removed and tested to experimentally verify the values used for Figure 3.6.4.

As described in paragraph 4.2.5 of the Safety Analysis report, detailed stress analyses have been made on the reactor vessel for both steady state and transient conditions with respect to material fatigue. The results of these transients are compared to allowable stress limits. Requiring the coolant temperature in an idle recirculation loop to be within 50°F of the operating loop temperature before a recirculation pump is started assures that the changes in coolant temperature at the reactor vessel nozzles and bottom head region are acceptable.

The plant safety analyses (Ref: NEDO-24204A) states that all MSIV valve closure - Flux scram is the event which satisfies the ASME Boiler and Pressure Code requirements for protection from the consequences of pressure in excess of the vessel design pressure. The reactor vessel pressure code limit of 1375 psig, given in Subsection 4.2 of the FSAR, is well above the peak pressure produced by the above overpressure event.

558246

3.6.D & 4.6.D BASES

Safety and Relief Valves

The safety/relief and safety valves are required to be operable above the pressure (122 psig) at which the core spray system is not designed to deliver full flow. The pressure relief system for each unit at the Peach Bottom APS has been sized to meet two design bases. First, the total capacity of the safety/relief and the safety valves has been established to meet the overpressure protection criteria of the ASME code. Second, the distribution of this required capacity between safety/relief valves and safety valves has been set to meet design basis 4.4.4.1 of subsection 4.4 of the FSAR which states that the nuclear system safety/relief valves shall prevent opening of the safety valves during normal plant isolations and load rejections.

The details of the analysis which shows compliance with the ASME code requirements is presented in subsection 4.4 of the FSAR and the Reactor Vessel Overpressure Protection Summary Technical Report presented in Appendix K of the FSAR.

Eleven safety/relief valves and two safety valves have been installed on Peach Bottom Unit 3 with a total capacity of 79.51% of rated steam flow. The analysis of the worst overpressure transient, (3-second closure of all main steam line isolation valves) neglecting the direct scram (valve position scram) results in a maximum vessel pressure of 1301 psig if a neutron flux scram is assumed. This results in a 74 psig margin to the code allowable overpressure limit of 1375 psig.

To meet the power generation design basis, the total pressure relief system capacity of 79.51% has been divided into 65.96% safety/relief (11 valves) and 13.55% safety (2 valves). The analysis of the plant isolation transient (Load Rejection with bypass valve failure to open) assuming a turbine trip scram is presented in NEDO-24204A. This analysis shows that the 11 safety/relief valves limit pressure at the safety valves to 25 psi below the setting of the safety valves. Therefore, the safety valves will not open.

Experience in safety/relief and safety valve operation shows that a testing of 50 per cent of the valves per year is adequate to detect failure or deteriorations. The safety/relief and safety valves are benchtested every second

558247

5.0 MAJOR DESIGN FEATURES

5.1 SITE FEATURES

The site is located partly in Peach Bottom Township, York County, partly in Drumore Township, Lancaster County, and partly in Fulton Township, Lancaster County, in southeastern Pennsylvania on the westerly shore of Conowingo Pond at the mouth of Rock Run Creek. It is about 38 miles north-northeast of Baltimore, Maryland, and 63 miles west-southwest of Philadelphia, Pennsylvania. Figures 2.2.1 through 2.2.4 of the FSAR show the site location with respect to surrounding communities.

5.2 REACTOR

- A. The core shall consist of not more than 764 fuel assemblies. 7 x 7 fuel assemblies shall contain 49 fuel rods and 8 x 8 fuel assemblies shall contain 62 or 63 fuel rods.
- B. One Pressurized Test Assembly may be inserted in the Core for up to four full fuel cycles.
- C. The reactor core shall contain 185 cruciform-shaped control rods. The control material shall be boron carbide powder (B₄C) compacted to approximately 70% of the theoretical density.
- D. One Fast Scram Control Rod Drive may be utilized during the fourth fuel cycle operation.

5.3 REACTOR VESSEL

The reactor vessel shall be as described in Table 4.2.2 of the FSAR. The applicable design codes shall be as described in Table 4.2.1 of the FSAR.

5.4 CONTAINMENT

558248

- A. The principal design parameters for the primary containment shall be as given in Table 5.2.1 of the FSAR. The applicable design codes shall be as described in Appendix M of the FSAR.
- B. The secondary containment shall be as described in Section 5.3 of the FSAR.
- C. Penetrations to the primary containment and piping passing through such penetrations shall be designed in accordance with standards set forth in Section 5.2.3.4 of the FSAR.