



LONG ISLAND LIGHTING COMPANY

SHOREHAM NUCLEAR POWER STATION

P.O. BOX 618, NORTH COUNTRY ROAD • WADING RIVER, N.Y. 11792

June 28, 1979

SNRC-403

Mr. Boyce Grier
Office of Inspection & Enforcement
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

LONG ISLAND LIGHTING COMPANY
SHOREHAM NUCLEAR POWER STATION - UNIT 1
DOCKET NO. 50-322

Dear Mr. Grier:

NRC Inspection and Enforcement Circular 79-05, dated March 20, 1979, addresses possible degradation of safety-related functions due to moisture leakage in stranded wire conductors. As recommended in the subject circular, we are reviewing equipment cabling configurations for areas where the potential of steam/moisture incursion might exist.

We wish to obtain all available data resulting from the equipment testing conducted at Sandia Laboratories (August 1978) as well as any other information in your possession which you feel would be helpful to us in addressing the concerns of this circular.

Please forward this information to Mr. B. R. McCaffrey, the LILCO Project Engineer, at the address shown on the letterhead above.

Very truly yours,

J. P. Novarro
Project Manager
Shoreham Nuclear Power Station

MAG:jm

cc: Mr. John G. Davis, Director
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555