

INDIANA & MICHIGAN POWER COMPANY

P. O. BOX 18
BOWLING GREEN STATION
NEW YORK, N. Y. 10004

July 5, 1979
AEP:NRC:00211

Donald C. Cook Nuclear Plant Units No. 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74

Mr. J. G. Keppler, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137


Dear Mr. Keppler:

This letter responds to your letter of May 22, 1979 which we received on May 25, 1979 and which transmitted to us IE Bulletin No. 79-11 entitled "Faulty Over-current Trip Device In Circuit Breakers for Engineered Safety Systems."

In regard to the actions required by your Bulletin 79-11, we have found that the Donald C. Cook Nuclear Plant does not utilize the Westinghouse type DB-75 breakers on safety related Class IE circuits. Therefore, no further action is required under Items 1, 2 and 3.

Item 4 requires a review of procedures and test schedules for all safety-related circuit breakers. This review has been conducted and we have determined that all safety related breakers shall be tested at each refueling outage, as of the next Unit 2 refueling outage now scheduled for about October 1979, to confirm over-current time delay protection.

Very truly yours,


John E. Dolan
Vice President

JED:em

cc: (Attached)

497 360

JUL 9 1979

7908080366

Mr. J. G. Keppler, Director

-2-

AEP:NRC:00211

cc: R. W. Jurgensen
D. V. Shaller - Bridgman
R. C. Callen
G. Charnoff

497 361