



**PUBLIC
SERVICE
INDIANA**

James Coughlin
Vice President
Nuclear

July 20, 1979

Mr. James G. Keppler, Director
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Docket Nos: STN50-546
STN50-547

Construction Permit Nos: CPPR-170
CPPR-171


**MARBLE HILL NUCLEAR GENERATING STATION, UNITS 1&2
I&E BULLETIN NO. 79-11**

Dear Mr. Keppler:

This is in response to I&E Bulletin No. 79-11, which is due by July 21, 1979.

Public Service Company of Indiana, Inc. (PSI) has evaluated your request for information concerning faulty overcurrent trip devices in circuit breakers for engineered safety systems contained in I&E Bulletin No. 79-11. We have reviewed the 480v switchgear circuit breaker types provided on the Marble Hill project. PSI wishes to inform you that there are no Westinghouse type DB circuit breakers currently being planned for use on the Marble Hill project.

Sincerely,


James Coughlin
Vice President-Nuclear

SJB:jbw

cc: U. S. Nuclear Regulatory Commission
Office of Inspection & Enforcement
Division of Reactor Construction Inspection
Washington, D.C. 20555

Mr. Edward R. Schweibinz
U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

678019

JUL 23 1979

7908150 445