

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

June 29, 1979

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. O. D. Parr, Chief
Light Water Reactors Branch No. 3
Division of Project Management
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Serial No. 526

LQA/RMN:esh

Docket Nos. 50-338
50-339

License No. NPF-4

Dear Mr. Denton:

ADDITIONAL INFORMATION ON
HIGH DENSITY SPENT FUEL RACKS

Mr. A. W. Dromerick, a member of your staff, has asked by phone about the minimum center to center spacing between fuel assemblies in adjacent high density spent fuel racks. This spacing is $14\frac{1}{2}$ inches assuming the two racks are as close as possible.

Very truly yours,

W. C. Stallings
C. M. Stallings

Vice President-Power Supply
and Production Operations

cc: Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
Region II

280 169

7907 030300