

## LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

CON'T

REPORT SOURCE: L 0 1 5 0 0 0 3 1 3 0 0 5 2 2 7 9 0 6 2 7 7 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

0 2 1 During a routine maintenance investigation, cable leads at location C-46,

0 3 1-8-5 termination 2 & 6 were found to be lifted, but were not tagged

0 4 in accordance with procedure 1005.04, "Control & Use of Bypass Jumpers."

0 5 The lifted leads prevents the automatic opening of ICS control emergency

0 6 feedwater valves CV.2670 & CV. 2620; however, they were operable by manual

0 7 control. There have been no similar occurrences. Reportable per special

0 8 NRC request.

0 9

SYSTEM CODE: Z Z 11

CAUSE CODE: Z 12

CAUSE SUBCODE: Z 13

COMPONENT CODE: Z Z Z Z Z Z 14

COMP SUBCODE: Z 15

VALVE SUBCODE: Z 16

EVENT YEAR: 7 9

SEQUENTIAL REPORT NO: N 17

OCCURRENCE CODE: 9 18

REPORT TYPE: X 19

REVISION NO: 0 20

ACTION TAKEN: B 18

FUTURE ACTION: H 19

EFFECT ON PLANT: Z 20

SHUTDOWN METHOD: Z 21

HOURS: 0 22

ATTACHMENT SUBMITTED: N 23

PRIME COMP SUPPLIER: Z 25

COMPONENT MANUFACTURER: Z 19 19 19 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

0 1 The valves were actuated automatically last on 12/31/78. A search of

0 2 maintenance documentation failed to reveal when or why leads were

0 3 lifted, but it is postulated that they were lifted during the present

0 4 refueling outage. The leads were reconnected and the valves proven

0 5 operable. I & C and electrical personnel to review occurrences report.

0 6

FACILITY STATUS: H 28

% POWER: 0 29

OTHER STATUS: NA 30

METHOD OF DISCOVERY: A 31

DISCOVERY DESCRIPTION: NA 32

ACTIVITY CONTENT RELEASED OF RELEASE: Z 33

AMOUNT OF ACTIVITY: NA 35

LOCATION OF RELEASE: NA 36

PERSONNEL EXPOSURES NUMBER: 0 37

TYPE: Z 38

DESCRIPTION: NA 39

PERSONNEL INJURIES NUMBER: 0 40

DESCRIPTION: NA 41

LOSS OF OR DAMAGE TO FACILITY TYPE: Z 42

DESCRIPTION: NA 43

PUBLICITY ISSUED: N 44

DESCRIPTION: NA 45

NRC USE ONLY

NAME OF PREPARER: Chris N. Shively

501/968-2519

282 006

7907030 398

5