



**Duquesne Light**

435 Sixth Avenue  
Pittsburgh, Pennsylvania  
15219

TERA

(412) 471-4300

May 17, 1979

United States Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

ATTENTION: Mr. Boyce H. Grier, Director

SUBJECT: Beaver Valley Power Station - Unit No. 2  
Docket No. 50-412  
IE Bulletin No. 79-03  
Longitudinal Weld Defects in ASME SA-312  
Type 304 Stainless Steel Pipe Spools  
Manufactured by Youngstown Welding and  
Engineering Company

Gentlemen:

Pursuant to the above, please be advised that no welded type ASME SA-312, Type 304, or other welded (without filler material) pipe manufactured by Youngstown Welding and Engineering Company, is being used or will be used for piping, fitting, or pipe supports for safety-related systems of Beaver Valley Power Station - Unit No. 2. Confirmation of this fact has been obtained from the piping and pipe support suppliers for this project.

DUQUESNE LIGHT COMPANY

BY

E. J. Woolever  
Vice President

cc: Dr. E. Volgenan (15)  
Mr. W. G. McDonald (1)

281 103

7907050 398 Q