

No. 3-79-16/037-0

This LER refers to the setpoint drift of reactor pressure switch (PS 3-2-3-52B). The applicable Technical Specifications are 6.9.2.b(2), 3.2.B, and Table 3-2.B.

LICENSEE EVENT REPORT

CONTROL BLOCK										(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)									
P A P B S 3 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4										L I C E N S E E C O D E L I C E N S E N U M B E R L I C E N S E T Y P E C A T									
CON'T REPORT SOURCE 1 6 0 5 0 - 0 2 7 8 7 0 6 2 8 7 9 8 0 7 2 4 7 9 9										D O C K E T N U M B E R E V E N T D A T E R E P O R T D A T E									
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES																			
While at power, a routine surveillance test revealed the set point of																			
PS 3-2-3-52B switch number 2 was 20 psig below the Tech Spec minimum of																			
200 psig specified in Table 3.2.B. This switch is one of four that																			
closes recirculation pump discharge valves under LOCA conditions. Safety																			
significance was minimal since all redundant channels had been proven																			
operable and in calibration within the previous two weeks.																			
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE																			
I B 11 E 12 E 13 I N S T R U 14 S 15 Z 16																			
LER NO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO OCCURRENCE CODE REPORT TYPE REVISION NO																			
7 9 - 0 1 6 / 0 3 L 0																			
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER																			
E 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 N 25 B O S C 44																			
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS																			
Instrument PS 3-2-3-52B, Barton Model 288, was out of calibration due to																			
instrument set point drift. The instrument was immediately recalibrated,																			
satisfactorily surveillance tested, and returned to service.																			
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION																			
E 28 1 0 0 0 N/A B 31 Surveillance Test																			
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE																			
Z 33 Z 34 N/A N/A																			
PERSONNEL EXPOSURES PERSONNEL INJURIES LOSS OF OR DAMAGE TO FACILITY PUBLICITY ISSUED																			
0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0																			
N/A N/A N/A N/A																			
POOR ORIGINAL																			
7907270238																			
NAME OF PREPARER M. J. Cooney PHONE 215-841-5020																			