



**LOUISIANA**  
**POWER & LIGHT**

142 DELARONDE STREET  
P O BOX 6008 • NEW ORLEANS, LOUISIANA 70174 • (504) 366-2345

D. L. ASWELL

Vice President-Power Production

August 7, 1979

LPL 11738  
3-A1.01.04  
3-A34.02

Director of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

SUBJECT: Waterford 3 SES  
Docket No. 50-382  
Reexamination of Partial Exemption  
From Requirements of 10CFR Part 21

REFERENCE: NRR letter H. R. Denton to D. L. Aswell dated November 21, 1978

Dear Sir:

The referenced letter advised Louisiana Power & Light Company to reexamine our July 28, 1978 request for exemption in light of the October 19, 1978 amendment to 10CFR Part 21.

We have completed our review of this matter and conclude that a partial exemption is no longer required for General Electric (GE) type CR terminal blocks to be used in nine safety-related control panels at Waterford SES Unit No. 3.

The terminal blocks meet the definition of "commercial grade item" as defined in 10CFR21. These blocks are catalog items (Model #CR151B2) and no unique requirements were specified to GE for nuclear application. GE Type CR terminal blocks are used in other than nuclear facilities.

We do understand that these terminal blocks are now dedicated for use as basic components. Therefore LP&L's, Ebasco Services' and Frank Electric's responsibilities under Part 21 are not affected by the amendments to Part 21.

General Electric Company is supplying blocks that are exempted from 10CFR21.

Yours very truly,

  
D. L. Aswell

DLA/RWP/ddc

cc: E. Blake  
W. Stevenson

7908130 398

561 316  
3006  
S 1/0