



Duquesne Light

435 Sixth Avenue
Pittsburgh, Pennsylvania
15219

(412) 471-4300

DUQUESNE LIGHT COMPANY
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15077

August 1, 1979
BVPS:JAW:697

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
LERs 78-53/01T-1, 79-08/01T-1, 79-10/01T-1,
79-14/01T-1, 79-15/01T-1, 79-24/01T-0

Mr. B. H. Grier, Director Regulation
United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

In accordance with Appendix A, Beaver Valley Technical Specifications, the following updated Licensee Event Reports and Licensee Event Report are submitted;

LER 78-53/01T-1, Technical Specification 6.9.1.8.i, Error in Safety Injection system piping stress analysis.

LER 79-08/01T-1, Technical Specification 6.9.1.8.h, Potential for single dropped rod to lead to calculated DNB ratios lower than reported in the safety analysis.

LER 79-10/01T-1, Technical Specification 6.9.1.8.i, Potential for failure of the inside recirculation spray pump motors.

LER 79-14/01T-1, Technical Specification 6.9.1.8.i, Steam generator nozzle to feedwater piping weld cracking.

LER 79-15/01T-1, Technical Specification 6.9.1.8.h, Possible steam generator level instrument error from high energy line break in containment.

LER 79-24/01T-0, Technical Specification 6.9.1.8.i, Solenoid valves in containment with deficiencies in environmental qualifications.

Very truly yours,

HP Williams

for J. A. Werling 561 217
Superintendent

Attachment

A002
5 111 7 908 130 419

Mr. B. H. Grier
August 1, 1979
BVPS:JAW:697
Page 2

cc: Director Of Management & Program Analysis
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. L. Wigginton, BVPS Licensing Project Manager
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. A. Beckman, Nuclear Regulatory Commission, King of Prussia, PA

G. A. Olson, Secretary, Prime Movers Committee - EEI

561 218