

PUBLIC SERVICE COMPANY OF OKLAHOMA

A CENTRAL AND SOUTH WEST COMPANY

P.O. BOX 201 / TULSA, OKLAHOMA 74102 / (918) 583-3611

Public Service Company of Oklahoma
Black Fox Station
Response to Staff Request for Clarification
PSO Submittal of 7/27/79
USNRC Docket Nos. STN 50-556, 50-557

6212DIN8-017-122



August 8, 1979
File 6212.125.3500.21L
6212.217.0521.21L

Mr. Steven A. Varga, Assistant Director
Division of Project Management
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20002

Dear Mr. Varga:

On July 27, PSO submitted its response to the regulatory staff's construction permit requirements with respect to TMI-2. Subsequently, your Project Manager, Dr. Cecil O. Thomas, has discussed several items with our Manager, Licensing and Compliance, Vaughn L. Conrad, in connection with the preparation of a Safety Evaluation Report supplement. Based on those conversations, we wish to clarify PSO's intent in connection with several issues. These explanations are intended to augment and carry the same weight as the commitments made in our referenced document. It is PSO's express intent to document the implementation of these TMI-2 related commitments in the FSAR.

- Page 5 - PSO analysis of accidents and anticipated operational occurrences will use Regulatory Guide 1.70, Revision 2. The analysis will include applying single failures chosen so that the dynamic forces on the safety and relief valves are maximized.
- Page 6 - PSO will determine a method acceptable to the regulatory staff to provide a reliable safety and relief valve position indication in the control room for the nineteen reactor main steam safety/relief valves in each nuclear steam supply system. It is expected that such indication will be derived from a reliable valve position detection device or a reliable indication of flow in the discharge pipe.
- Page 7 - PSO will utilize the analysis described in NUREG 0578, Appendix A, Section 2.1.9 to form a basis for operator training and procedure development to the end of aiding the operator in recognizing and mitigating inadequate core cooling.

Boo!
SE 1/0 678245

CENTRAL AND SOUTH WEST SYSTEM

Central Power and Light
Corpus Christi, Texas

Public Service Company of Oklahoma
Tulsa, Oklahoma

Southwestern Electric Power
Shreveport, Louisiana

West Texas Utilities
Arlene, Texas


7908150481

August 8, 1979
Page Two

- Page 25 - PSO will assign normal duties to the shift technical advisors that pertain to the engineering aspects of assuring safe operation of the plant, including the review and evaluation of operating experience.
- Page 28 - PSO will maintain the set of as built drawings and other records as described in ANSI N45.2.9-1974.
- Page 45 Section ii - PSO recognizes that information derived from the instrumentation described in NUREG 0578, Appendix A, Section 2.1.8 will be related to the emergency plan action levels.
- Page 45 Section iii - PSO recognizes that communication between the Emergency Operations Center and the Technical Support Center described in NUREG 0578, Appendix A, Section 2.2.2.b is required. Moreover, we will evaluate the relationship between the two centers in establishing locations and instrumentation provided therein.
- Page 46 Section v - PSO recognizes that local coordination, as well as state agencies', will be required in development of the BFS radiological emergency response plan. The draft state plan addresses the required local jurisdiction planning as a subset of the state activity. The local agreements will be documented in the BFS Emergency Plan at the time of FSAR submittal.

We understand that upon receipt of these clarifications the SER supplement will be issued in the next day or two.

Very truly yours,



T. N. Ewing, Manager
Black Fox Station Project

TNE:VLC:jk

cc: BFS Service List

678246

BLACK FOX STATION SERVICE LIST

Mr. Lawrence Burrell
Route 1, Box 197
Fairview, OK 73737

Andrew T. Dalton
1437 So. Main St., Suite 302
Tulsa, OK 74119

L. Dow Davis, William D. Paton,
and Colleen Woodhead
Counsel for NRC Staff
USNRC
Washington, D.C. 20555

Mrs. Carrie Dickerson
Citizens Action for Safe Energy, Inc.
P. O. Box 924
Claremore, OK 74017

Mr. Gerald F. Diddle, Gen. Mgr.
Associated Electric Cooperative, Inc.
P. O. Box 754
Springfield, MO 65801

Joseph R. Farris, John R. Woodard III
Feldman, Hall, Franden, Reed and
Woodard
816 Enterprise Building
Tulsa, OK 74103

Mr. Joseph Gallo
Isham, Lincoln & Beale
1050 17th Street, N.W.
Washington, D.C.

Mr. William G. Hubacek
USNRC, Region IV
Office of Inspection and Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76012

Mr. Maynard Human, Gen. Mgr.
Western Farmers Electric Cooperative
P. O. Box 429
Anadarko, OK 73005

MHB Technical Associates, Inc.
1723 Hamilton Avenue, Suite K
San Jose, CA 95125

Michael I. Miller
Isham, Lincoln & Beale
One First National Plaza, Suite 4200
Chicago, IL 60603

Mr. Jan A. Norris
USNRC, Environmental Projects Branch 3
Phillips Building
7920 Norfolk Avenue
Bethesda, MD 20014

Charles S. Rogers, Asst. Attorney General
112 State Capitol Building
Oklahoma City, OK 73105

Mr. Cecil Thomas
USNRC
Phillips Building
7920 Norfolk Avenue
Bethesda, MD 20014

Mrs. Ilene Younghein
3900 Cashion Place
Oklahoma City, OK 73112

678247