

TIC

TEXAS UTILITIES GENERATING COMPANY

2001 BRYAN TOWER • DALLAS, TEXAS 75201

July 18, 1979

TXX-3012

R. J. GARY  
EXECUTIVE VICE PRESIDENT  
AND GENERAL MANAGER

Mr. W. C. Seidle, Chief  
Reactor Construction & Engineering  
Support Branch  
U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
611 Ryan Plaza Dr., Suite 1000  
Arlington, Texas 76012

Docket Nos. 50-445  
50-446


COMANCHE PEAK STEAM ELECTRIC STATION  
1981-83 2300 MW INSTALLATION  
ELECTRICAL CABLE TRAY HANGERS  
FILE NO: 10110

Dear Mr. Seidle:

On June 19, 1979, we verbally informed your Mr. R. G. Taylor of three (3) electrical cable tray hangers that were found to have light partial penetration welds where full penetration welds were required by the designer. We considered this "potentially" reportable under 10 CFR 50.55(e).

We are continuing our investigation and evaluation and will notify you as soon as we have reached a conclusion.

Very truly yours,

  
R. J. Gary

RJG:dla

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement - (15 copies)  
c/o Distribution Services Branch, DDC, ADM.  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

7908170112

756 126