

TEXAS UTILITIES GENERATING COMPANY

2001 BRYAN TOWER • DALLAS, TEXAS 75201

July 17, 1979  
TXX-3010

R. J. GARY  
EXECUTIVE VICE PRESIDENT  
AND GENERAL MANAGER

Mr. W. C. Seidle, Chief  
Reactor Construction & Engineering  
Support Branch  
U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
611 Ryan Plaza Dr., Suite 1000  
Arlington, Texas 76012

Docket Nos. 50-445  
50-446

COMANCHE PEAK STEAM ELECTRIC STATION  
1981-83 2300 MW INSTALLATION  
PIPE WALL THICKNESS  
FILE NO: 10110

Dear Mr. Seidle:

On May 22, 1979, we verbally informed your Mr. R. G. Taylor that pipe wall thickness requirements established in the project piping specifications may not have been adequately conservative to meet ASME code stress requirements. We considered this "potentially" reportable under 10 CFR 50.55(e).

We are continuing our investigation and evaluation and will notify you as soon as we have reached a conclusion.

Very truly yours,

*R. J. Gary*  
R. J. Gary

RJG:ljf

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement - (15 copies)  
c/o Distribution Services Branch, DDC, ADM.  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555



7908170120