

THE  
PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

PHILADELPHIA, PA. 19101

(215) 841-4500

V. S. BOYER  
VICE PRESIDENT

Mr. Boyce H. Grier  
United States Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

JUL 27 1979

SUBJECT: NRC Region 1 letter dated May 22, 1979  
RE: I.E. Bulletin No. 79-11  
"Faulty Overcurrent Trip Device in  
Circuit Breakers for Engineered Safety  
Systems".  
Limerick Generating Station Units 1 and 2  
Docket Nos. 50-352 and 50-353  
File: Gov't 1-1 (IE Bulletin 79-11)


Dear Mr. Grier:

Philadelphia Electric Company has reviewed I.E. Bulletin No. 79-11 submitted with the subject letter received on May 23, 1979.

We have determined that there are no Westinghouse type DB-50 and DB-75 Circuit Breakers used or planned for use in any safety related circuits at Limerick Generating Station.

Based on the above, we plan no further action on this item.

Sincerely,



Copy to: U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Division of Reactor Operations Inspection  
Washington, DC 20555

771350

7908200 OOS

Q