

TIC

DUKE POWER COMPANY

USNRC  
ATLANTA

ELECTRIC CENTER, BOX 33189, CHARLOTTE, N. C. 28242

L. C. DAIL  
VICE PRESIDENT  
DESIGN ENGINEERING

3 JUL 23 9:57

July 19, 1979


Mr. J. P. O'Reilly, Director  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

RE: Cherokee and Perkins Nuclear Stations  
IE Bulletin 79-11  
Duke Files: P81-1412.11, EGS A-5.3

Dear Mr. O'Reilly:

In response to your letter of May 22, 1979, which transmitted Nuclear Regulatory Commission IE Bulletin 79-11, we wish to advise that a review of the designs of Cherokee and Perkins Nuclear Stations has been conducted. This review revealed that no Westinghouse DB-50 or DB-75 circuit breakers are used or planned for use in safety related systems at this station.

Very truly yours,



L. C. Dail, Vice-President  
Design Engineering

EKM/cam

7908210114

841 156

79061  
~~79083~~

OFFICIAL COPY