

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE

NEW YORK, N. Y. 10019

(212) 397-6200



August 14, 1979  
JPN-79-48

Director of Nuclear Reactor Regulation  
United States Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. Thomas A. Ippolito, Chief  
Operating Reactors Branch No. 3  
Division of Operating Reactors

Subject: James A. FitzPatrick Nuclear Power Plant  
Docket No. 50-333  
Supplemental Information in Support of  
Request for Plant Start-up

Dear Sir:

In our letter of August 10, 1979, the Authority reported that analysis of 23 of 28 supports associated with the high pressure core injection system and reactor core isolation cooling system had been completed and that the supports were within allowable stress limits.

This letter informs you that analysis of the remaining five supports is now completed. These five supports will be modified prior to start-up even though none were determined to be inoperable as defined in our August 2, 1979 letter.

Very truly yours,

Paul J. Early  
Assistant Chief Engineer-  
Projects

761322

Acc'd  
S/O  
1/0

7908210 544 10 R