



Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address: Reply to: Post Office Box 767
Chicago, Illinois 60690

August 14, 1979

Mr. A. Bournia
Division of Project Management
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Environmental Qualification Requirements
LaSalle County Units 1 and 2
NRC Docket Nos. 50-373 and 50-374

Reference (a): O.D. Parr letter to L.O. Del George
dated December 21, 1978.

(b): O.D. Parr letter to L.O. Del George
dated February 5, 1979.

Dear Mr. Bournia:

At the meeting of May 24, 1979 between Commonwealth Edison and members of the NRR Staff, Mr. J. Knox (Power Systems Branch) requested that Commonwealth Edison delineate to the extent possible the NSSS equipment to be used at LaSalle County which is not common to that used at the Zimmer Station. The objective of this comparison was to minimize repeated effort in examining LaSalle County qualification records where such records had already been reviewed on the Zimmer docket.

Such a comparison of LaSalle County and Zimmer equipment (see FSAR Table 3.10) has been made, with few differences identified. The majority of the equipment are the same for both plants (type, vendor, etc.). The LaSalle County differences are listed below:

<u>MPL</u>	<u>Item</u>	<u>Vendor</u>
C61 N001	Flow Transmitter	Bailey
E22 S001	HPCS Battery Charger	C & D
B21 K613	Power Supply	Elma

764 122

7908210 571 18

Boo
SEED
110

Commonwealth Edison

NRC Docket Nos. 50-373
50-374

Mr. A. Bournia

- 2 -

August 14, 1979

It is hoped that this information will facilitate your review of items 5 and 9 respectively in Reference (a) and (b) with regard to NSSS equipment. Please direct any further questions in this regard to this office.

Very truly yours,



L. O. Del George
Nuclear Licensing Administrator