

THE CINCINNATI GAS & ELECTRIC COMPANY



E. A. BORGMANN  
VICE PRESIDENT

July 10, 1979  
QA-1167

U. S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Attention: Mr. James G. Keppler  
Director

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT I  
IE INSPECTION REPORT 50-358/79-12, CONSTRUCTION  
PERMIT NO. CPPR-88, DOCKET NO. 50-358, W.O. #  
57300-957, JOB E-5590

Gentlemen:

This letter constitutes our formal reply to the subject Inspection Report. It is our opinion that nothing in the report or in this reply is proprietary in nature.

Our response to the deficiency identified in Appendix "A" of the inspection report is as follows:

Welding on Pipe Whip Restraint Proceeded Without Documentation that Inspection Had Been Performed

1. Corrective Action Taken and Results Achieved

The inspection points on Henry J. Kaiser KE-1 forms for Welds No. 8, 9, 10, 11, 12 and 13 on MSK 2B-618 were not properly stamped. Activities had been witnessed; however, transfer of this information from supplemental records had not been completed. Continuation of subsequent work activities proceeded based on the knowledge that the previous hold points had been witnessed. The delinquent records have been appropriately stamped to reflect completion of QC requirements.

2. Corrective Action Taken to Avoid Further Noncompliance

All inspectors were informed on May 1, 1979 as to the requirements for fully documented witness points and maintenance of such records on a current basis. All records will be reviewed for completeness prior to acceptance and filing. These records shall be reviewed

782252  
JUL 13 1979  
7908230 128

Mr. James G. Keppler, Director  
U. S. Nuclear Regulatory Commission  
Region III  
July 10, 1979 - QA-1161

prior to preparation of Code Data Reports and system turnover  
for preoperational testing.

3. The Date When Full Compliance Will Be Achieved

Full compliance will be achieved upon turnover of the final  
system for preoperational testing. Pipe whip restraint  
records will be reviewed and accepted by July 13, 1979.

We trust this information will provide an adequate response to your IE  
Inspection Report #79-12.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY



By

E. A. BORGMANN  
VICE PRESIDENT

WWS:pa

762253