



7x
Jersey Central Power & Light Company
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960
(201) 455-8200
File: 2421.13

July 30, 1979

Mr. Boyce H. Grier, Director
Office of Inspection and Enforcement
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Dear Mr. Grier:


SUBJECT: FORKED RIVER NUCLEAR STATION
LICENSE NO. CPPR-96
DOCKET NO. 50-363
I&E BULLETIN 79-02 AND 79-02 REV. 1

This letter is in response to I&E Bulletins 79-02 and 79-02 (Rev. 1) entitled "Pipe Support Base Plate Designs Using Concrete Expansion Anchor Bolts," dated March 8, 1979 and June 21, 1979, respectively.

The provisions of the bulletin do not apply to Forked River, since Forked River pipe support base plate designs do not include concrete expansion anchor bolts.

If you have any questions concerning the above, please do not hesitate to contact me.

Very truly yours,


Ivan R. Finfrock, Jr.
Vice President

asb

cc: Director, Office of Inspection &
Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

774035

7908230154