

LICENSEE EVENT REPORT

CONTROL BLOCK:

						(1)
--	--	--	--	--	--	-----

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 7 8 N C B E P 2 14 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 57 CAT 58 5

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T

0 1 7 8 REPORT SOURCE L 6 0 5 0 - 0 3 2 4 7 1 2 0 2 7 8 8 0 8 2 0 7 9 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During a routine panel check on 12-2-78, the control operator noticed that the recorder

0 3 | for the chloride intrusion monitor, CO-CIS-3075-1 (Condensate Pump Discharge), was not

0 4 | indicating. Further investigation revealed that the detector was malfunctioning.

0 5 | Technical Specification 3.3.5.6, 6.9.1.9b

0 6 |

0 7 |

0 8 |

SYSTEM CODE H H		CAUSE CODE E		CAUSE SUBCODE G		COMPONENT CODE I N S T R U				COMP. SUBCODE E		VALVE SUBCODE Z					
EVENT YEAR 7 8		SEQUENTIAL REPORT NO. 0 7 6		OCCURRENCE CODE 0 3		REPORT TYPE X		REVISION NO. 1									
ACTION TAKEN A		FUTURE ACTION Z		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED N		NPRD-4 FORM SUB. M		PRIME COMP. SUPPLIER A		COMPONENT MANUFACTURER L 1 3 0	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The detector was bad and therefore, was replaced from stock. The instrument was cal-
1 1 ibrated and returned to service. This is considered an isolated event and no further
1 2 action is required.
1 3
1 4

FACILITY STATUS				% POWER				OTHER STATUS				METHOD OF DISCOVERY				DISCOVERY DESCRIPTION			
1	5	E	28	0	6	7	29	NA	30	A	31	Operator Surveillance				32			
ACTIVITY CONTENT				RELEASED OF RELEASE				AMOUNT OF ACTIVITY				LOCATION OF RELEASE							
1	6	Z	33	Z	34	NA	35	NA	36										
PERSONNEL EXPOSURES				PERSONNEL INJURIES				LOSS OF OR DAMAGE TO FACILITY				PUBLICITY							
NUMBER				NUMBER				TYPE				ISSUED							
1	7	0	0	0	0	0	40	0	0	0	41	NA	42	NA	43	NA	44	NA	45
DESCRIPTION				DESCRIPTION				DESCRIPTION				DESCRIPTION							
774290				7908230561															
NRC USE ONLY																			

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-9521