

P. O. BOX 33189

DUKE POWER COMPANY
GENERAL OFFICES
422 SOUTH CHURCH STREET
CHARLOTTE, N. C. 28242
19 JUL 19 A 8:51

TELEPHONE: AREA 704
373-4011

July 16, 1979


Mr. J. P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Re: Perkins and Cherokee Nuclear Stations
IE Bulletin 79-09
Duke Files: P81-1412.11, EGS A-5.3

Dear Mr. O'Reilly:

In response to your letter of April 17, 1979, which transmitted Nuclear Regulatory Commission IE Bulletin 79-09, we wish to advise that a review of the design of Perkins and Cherokee Nuclear Stations has been conducted. This review revealed that no GE Type AK-2 circuit breakers are used or planned for use in safety-related systems at these stations.

Very truly yours,



L. C. Dail, Vice President
Design Engineering Department

EKM/sr

774199

79059

7908230 648 OFFICIAL COPY