

U-771

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT
 0 1
 7 6

REPORT SOURCE 1 0 0 5 0 0 0 3 2 1 7 0 3 0 1 7 9 5 0 8 1 7 7 9 9
 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing normal surveillance procedure HNP-1-3001, High Reactor Pressure

0 3 | Instrumentation Functional Test and Calibration, high reactor pressure trip switch

0 4 | B21-N023B was found to actuate at 1075 psig. The setpoint is 1049 ± 10 psig. This

0 5 | switch gives one-half scram signal to reactor protection system. Redundant switches

0 6 | N023 A, C, and D were within tolerance. Public health and safety were not affected.

0 7 |

0 8 |

7 6 9 80

SYSTEM CODE 0 0		CAUSE CODE 1 A (11)		CAUSE SUBCODE E (12)		COMPONENT CODE B (13) I N S T R U (14)				COMP. SUBCODE E (15)		VALVE SUBCODE Z (15)	
7 8		9 10		11		12 13		14 15		16 17		18 19	
LER NO. REPORT NUMBER (17) 7 9		EVENT YEAR 21 22		SEQUENTIAL REPORT NO. 23 24 25 26		OCCURRENCE CODE 27 28 29		REPORT TYPE 30 31		REVISION NO. 32 33			
ACTION TAKEN E (18) 0 4 (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD 34 35 Z (21)		HOURS 36 37 38 39 40		ATTACHMENT SUBMITTED N (22)		NPR-4 FORM SUB. Y (24)		PRIME COMP. SUPPLIER N (25)	
33 34		35 36		37 38 39 40		41 42		43 44		45 46		47 48	
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)													

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Cause of the event was setpoint drift. The switch was recalibrated by HNP-1-5279,
1 1 Barksdale Pressure Switch Calibration, and the functional test successfully
1 2 completed. Similar LER's are 79-043, 78-074, 78-055.
1 2
1 4

FACILITY STATUS		N POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	4	22	0	0	0	30	B	31
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	7	32	2	34	NA	35	NA	36
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			
1	7	0	0	0	37	2	38	NA	
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	0	0	0	39	NA	40		
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	7	41	NA	42				
PUBLICITY		NUMBER		DESCRIPTION					
1	10	7	43	NA	44				

NRC USE ONLY

NRC USE ONLY

7908240339

POOR ORIGINAL