


ILLINOIS POWER COMPANY



U-0100  
L08-79(07-26)-0

500 SOUTH 27TH STREET, DECATUR, ILLINOIS 62525

July 26, 1979

Mr. James G. Keppler  
Director, Region III  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

Clinton Power Station Units 1 & 2  
Docket Nos. 50-461 and 50-462  
Construction Permits No. CPPR-137 & CPPR-138

This is in reply to your letter of May 22, 1979, whereby you forwarded IE Bulletin No. 79-11 which reported on a problem encountered with faulty overcurrent trip devices in circuit breakers.

Please be advised that Westinghouse DB-75 and DB-50 circuit breakers will not be used with any safety related services at the Clinton Power Station.

Sincerely,

G. E. Wuller  
Supervisor - Licensing  
Generation Engineering Department

GEW/jh

cc: Director, Division of Reactor Operations Inspection  
Office of Inspection & Enforcement, USNRC

790824-0634

775 050  
JUL 30 1979