

TIC

SCE

Southern California Edison Company

P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

K. P. BASKIN

MANAGER, GENERATION ENGINEERING

June 29, 1979

TELEPHONE
213-572-1401



U. S. Nuclear Regulatory Commission
Region V
Suite 202, Walnut Creek Plaza
1990 N. California Boulevard
Walnut Creek, California 95696

Attention: Mr. R. H. Engelken

Gentlemen:

Subject: IE Bulletin 79-11
Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 2 and 3

Your letter of May 22, 1979 forwards IE Bulletin 79-11, "Faulty Overcurrent Trip Device in Circuit Breakers for Engineered Safety Systems" and requests information concerning the extent of use of certain circuit breakers at San Onofre Units 2 and 3.

It has been determined that none of the subject circuit breakers (Westinghouse Model DB-50 and DB-75) are in use, planned for use, or in spares at San Onofre Units 2 and 3. Additionally, our A/E has been instructed to ensure the subject breakers are not purchased in the future.

Should you have any questions or require further clarification, please contact me.

Very truly yours,

KP Baskin

cc: U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D.C. 20555

7909040317

302271

77-100