LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 4 | M A P P S 1 (2) | 0 0 0 0 0 0 0 0 0 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T

0 1 | REPORT SOURCE L (6) | 0 5 0 - 0 2 9 3 (7) | 0 8 1 6 7 9 (8) | 0 8 2 8 7 9 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During a seismic event with or without LOCA, the unit auxiliary transformer breakers
0 3 A505 and A605 may not be tripped open automatically by the existing trip signals because
0 4 these trip signals come from non seismically qualified sources. Hence the emergency
0 5 diesel generator breakers A509 and A609 could not close automatically since the unit
0 6 auxiliary breakers are not tripped.
0 7
0 8

SYSTEM CODE: E E (11) | CAUSE CODE: B (12) | CAUSE SUBCODE: A (13) | COMPONENT CODE: Z Z Z Z Z Z (14) | COMP. SUBCODE: Z (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 9 | — | SEQUENTIAL REPORT NO. 0 3 1 | / | OCCURRENCE CODE 0 1 | REPORT TYPE T | — | REVISION NO. 0

ACTION TAKEN: F (18) | FUTURE ACTION: Z (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 0 | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB.: N (24) | PRIME COMP. SUPPLIER: Z (25) | COMPONENT MANUFACTURER: Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

0 The aux. trip relays associated with the trip logic for the unit aux. breakers were
1 not originally specified to be seismically qualified. The unit aux. transformer
2 breaker control circuits have been modified so a trip will occur from an undervoltage
3 at A5 and A6 buses by utilizing spare contacts of seismically qualified undervoltage
4 relays. These trips are a backup to the original trip circuits.

FACILITY STATUS: E (28) | % POWER: 1 0 0 (29) | OTHER STATUS (30): N.A. | METHOD OF DISCOVERY: D (31) | DISCOVERY DESCRIPTION (32): Design Analysis

ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): N.A. | N.A. | LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES — NUMBER: 0 0 0 (37) | TYPE (38) | DESCRIPTION (39): N.A.

PERSONNEL INJURIES — NUMBER: 0 0 0 (40) | DESCRIPTION (41): N.A.

LOSS OF OR DAMAGE TO FACILITY — TYPE: Z (42) | DESCRIPTION (43): N.A.

PUBLICITY — ISSUED: N (44) | DESCRIPTION (45): N.A.

NRC USE ONLY

NAME OF PREPARER: John M. Fulton 7909040345 PHONE: 617-746-7900

302335