



Commonwealth Edison

Quad Cities Nuclear Power Station
22710 206 Avenue North
Cordova, Illinois 61242
Telephone 309/654-2241

NJK-79-319

August 30, 1979

J. Keppler, Regional Director
Office of Inspection and Enforcement
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

SUBJECT: Quad-Cities Nuclear Power Station Semi-Annual
Report - Dockets 50-254 and 50-265

Dear Mr. Keppler:

Attached is the Errata from the Semi-Annual report pertaining to Radioactive Effluents Discharge for Quad-Cities Nuclear Power Station Unit 1 and 2 for the period of January 1, 1979 through June 30, 1979, as required by the Technical Specifications.

One copy of this report is provided for your use, and 39 copies are being transmitted by this letter to the Director, Office of Nuclear Reactor Regulation.

Very truly yours,

N. J. Kalivianakis
Station Superintendent

NJK:MW:aaa

Enclosure

P.S. The enclosed Errata is due to the receipt of outstanding analysis from our contractor on August 27, 1979.

308356

7909050389

Quad-Cities Errata
Semi-Annual Report - Second Quarter 1979

Table 1A	Change From	To
B. Iodines 2nd Quarter 1979		
3. Percent of Tech Spec limit	Blank	2.45
C. Particulates		
1. Particulates with half live > 8 days	Blank	2.76E-01
2. Average release rate for period	Blank	3.51E-02
3. Gross Alpha radioactivity	Add C1 in unit column	
D. Tritium		
1. Total release	Blank	7.90E+01
2. Average release rate for period	Blank	1.00E+01

Table 1B		
3. Particulates		
Sr 89	Blank	4.97E-02
Sr 90	Blank	3.00E-04

Table 1C		
3. Particulates		
Sr 89	Blank	1.79E-03
Sr 90	Blank	3.13E-04

Table 2A		
B. Tritium		
1. Total release	Blank	2.71E+00
2. Average diluted concentration	Blank	1.07E-08
3. Percent of applicable limit	Blank	3.57E-04

Table 2B		
Liquid Effluents		
Sr 89	Blank	1.63E-04
Sr 90	Blank	1.34E-04
Unidentified	Blank	6.54E-02
Total for period (above)	Blank	1.04E-01

868357