

## U. S. NUCLEAR REGULATORY COMMISSION

/ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

REPORT SOURCE L 6 0 5 0 0 0 3 6 6 7 0 8 1 3 7 9 8 0 8 2 9 7 9 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

While performing routine surveillance procedure HNP-2-3005, Main Steam Line Radiation

Monitor Functional Test and Calibration, instrument 2D11-K603B setpoint was found to

be 2700 mr/hr. The Tech. Spec. acceptance criteria requires a setpoint of  $2175 \pm 10\%$

1 mr/hr. There was no effect on the environs. A similar occurrence was reported on

1 LER-2-79-053.

|                         |  |                                      |  |                              |  |                                  |  |                           |  |                              |  |                          |  |                              |  |  |  |
|-------------------------|--|--------------------------------------|--|------------------------------|--|----------------------------------|--|---------------------------|--|------------------------------|--|--------------------------|--|------------------------------|--|--|--|
| SYSTEM CODE<br>C C 11   |  | CAUSE CODE<br>E 12                   |  | CAUSE SUBCODE<br>E 13        |  | COMPONENT CODE<br>I N S T R U 14 |  | COMP. SUBCODE<br>S 15     |  | VALVE SUBCODE<br>Z 16        |  |                          |  |                              |  |  |  |
| EVENT YEAR<br>7 9 21 22 |  | SEQUENTIAL REPORT NO.<br>0 9 2 24 26 |  | OCCURRENCE CODE<br>0 3 28 29 |  | REPORT TYPE<br>L 30              |  | REVISION NO.<br>0 32      |  |                              |  |                          |  |                              |  |  |  |
| ACTION TAKEN<br>E 18    |  | FUTURE ACTION<br>Z 19                |  | EFFECT ON PLANT<br>Z 20      |  | SHUTDOWN METHOD<br>Z 21          |  | HOURS<br>0 0 0 0 22 27 40 |  | ATTACHMENT SUBMITTED<br>N 23 |  | NPRO-4 FORM SUB.<br>N 24 |  | PRIME COMP. SUPPLIER<br>N 25 |  | COMPONENT MANUFACTURER<br>G 0 8 0 26 44 47 |  |

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

Instrument drift was attributed as the cause for the problem. The instrument was

recalibrated per HNP-2-5100 and returned to service.

|                               |    |                    |     |                     |   |                      |  |                       |  |
|-------------------------------|----|--------------------|-----|---------------------|---|----------------------|--|-----------------------|--|
| FACILITY STATUS               |    | % POWER            |     | OTHER STATUS        |   | METHOD OF DISCOVERY  |  | DISCOVERY DESCRIPTION |  |
| 1                             | 5  | E                  | 099 | NA                  | B | Routine Surveillance |  |                       |  |
| ACTIVITY CONTENT              |    | AMOUNT OF ACTIVITY |     | LOCATION OF RELEASE |   |                      |  |                       |  |
| 1                             | 6  | Z                  | NA  | NA                  |   |                      |  |                       |  |
| PERSONNEL EXPOSURES.          |    | DESCRIPTION        |     |                     |   |                      |  |                       |  |
| 1                             | 7  | 000                | Z   | NA                  |   |                      |  |                       |  |
| PERSONNEL INJURIES            |    | DESCRIPTION        |     | 96-287              |   |                      |  |                       |  |
| 1                             | 4  | 000                |     | NA                  |   |                      |  |                       |  |
| LOSS OF OR DAMAGE TO FACILITY |    | DESCRIPTION        |     | 7909050 489         |   |                      |  |                       |  |
| 1                             | 1  | Z                  |     | NA                  |   |                      |  |                       |  |
| PUBLICITY                     |    | DESCRIPTION        |     | NRC USE ONLY        |   |                      |  |                       |  |
| 2                             | 11 | N                  |     | NA                  |   |                      |  |                       |  |

NAME OF PREPARER R. T. Nix

PHONE 912-367-7781

NRC USE ONLY