

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

REPORT SOURCE L 6 0 5 0 0 0 3 6 6 7 0 8 1 4 8 7 9 8 0 8 2 9 7 9 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

While performing normal surveillance procedure HNP-2-3105, for Main Steam Line Pressure Instrument Functional Test and Calibration, 2B21-N015A was found to have a setpoint of 835 psig decreasing. The Tech. Spec. acceptance criteria requires a setpoint of greater than or equal to 825 p plus 15 psig head correction. There was no effect on the environs. No previous occurrences of this type have been reported.

108		7		6-9		80																	
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMP. SUBCODE		VALVE SUBCODE															
C	C	11	E	12	E	13	I	N	S	T	R	U	14	S	15	Z	16						
9		10		11		12		13		14		15		16		17							
EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.															
7	9	21	22	—	23	0	9	3	24	25	0	3	26	27	L	28	29	30	31	32			
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER							
E	18	Z	19	Z	20	Z	21	0	0	0	0	22	N	23	N	24	N	25	B	0	6	9	26
33		34		35		36		37		40		41		42		43		44		47			

The problem was attributed to setpoint drift. The instrument was recalibrated per HNP-2-5279 and returned to service.

7	8	9	FACILITY STATUS										% POWER										OTHER STATUS										METHOD OF DISCOVERY										DISCOVERY DESCRIPTION									
1	1	5	E	33	0	9	9	29	NA										B										Functional Test																							
7	8	9	ACTIVITY CONTENT										AMOUNT OF ACTIVITY										LOCATION OF RELEASE																													
1	1	6	Z	33	Z	34	NA										NA																																			
7	8	9	PERSONNEL EXPOSURES										DESCRIPTION																																							
1	1	7	0	0	0	37	Z	38	NA																																											
7	8	9	PERSONNEL INJURIES										DESCRIPTION																																							
1	1	4	0	0	0	40	NA																																													
7	8	9	LOSS OF OR DAMAGE TO FACILITY										DESCRIPTION																																							
1	1	1	Z	42	NA																																															
7	8	9	PUBLICITY										DESCRIPTION																																							
1	1	11	N	44	NA																																															
7	8	9	ISSUED										DESCRIPTION																																							
1	1	11																																																		

90-352

7909050 508

NRC USE ONLY

PHONE 912-367-7781