



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

PRODUCTION DEPARTMENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street - Suite 3100
Atlanta, Georgia 30303

August 31, 1979

ATTENTION: Mr. J. P. O'Reilly, Director

Dear Mr. O'Reilly:

SUBJECT Grand Gulf Nuclear Station
File 0270/15525/15526
Potential Reportable Deficiency
No. 79/05 - Interim Report No.
3
AECM-79/97

On February 23, 1979, Mississippi Power & Light Company notified Mr. W. B. Kenna or your office, of a potential reportable deficiency at the Grand Gulf Nuclear Station construction site. The deficiency concerns improper drawings supplied by the General Electric Company.

General Electric has issued a Field Deviation Disposition Request (FDDR) calling for changes in wire and cable lists. Consequently, all termination cabinet panels at the site are being reviewed against as-shipped drawings. We expect to submit the findings of this review in a final report by November 30, 1979.

Yours truly,

L. F. Dale
Nuclear Project Manager

JRF/pa

cc: Mr. N. L. Stampley
Mr. R. B. McGehee
Mr. T. B. Conner

Mr. John G. Davis, Director **THIS COPY FOR**
Division of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

bcc: Dr. D. C. Gibbs
Mr. Adrian Zaccaria
Mr. J. N. Ward
Mr. D. M. Lake
Mr. R. L. Scott
Mr. J. P. McGaughy
Mr. W. L. Nail
Mr. T. E. Reaves
Mr. C. K. McCoy
Mr. J. C. Fuller
File