

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 F L Q R P 3 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 - - 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

CON'T
01
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

REPORT SOURCE L G 0 5 0 - 0 3 0 2 0 8 2 3 7 9 0 9 1 3 7 9 9
60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 At 0845 in Mode 5, during the performance of the Fire Pump Operability and
03 Recirculation Procedure, SP-365, it was discovered that fire service valve
04 FSV-89 was closed. This isolated the Control Complex Deluge/Sprinkler System,
05 rendering it inoperable contrary to Tech. Spec. 3.7.11.2. Redundancy NA.
06 No effect upon plant or general public as the system was not required during
07 the period of inoperability. First reported occurrence of an event of this
08 type.
09
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60

SYSTEM CODE A B 11 CAUSE CODE A 12 CAUSE SUBCODE X 13 COMPONENT CODE V A L L V I E X 14 COMP SUBCODE E 15 VALVE SUBCODE D 16
17 LER NO REPORT NUMBER 18 EVENT YEAR 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

ACTION TAKEN X 15 X 16 EFFECT ON PLANT Z 17 SHUTDOWN METHOD Z 18 HOURS 0 0 0 0 40 ATTACHMENT SUBMITTED Y 41 NRC FORM 366 NRC USE ONLY PRIVATE COMP SUPPLIER A 42 COMPONENT MANUFACTURER M 0 0 3 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 The cause of this event can be attributed to person or persons unknown closing
11 FSV-89 without proper authorization. FSV-89 immediately opened and sealed re-
12 storing system operability within one half hour.
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60

FACILITY STATUS G 23 POWER 0 0 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Operator observation 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

PUBLICITY ISSUED DESCRIPTION NA 44
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

NAME OF PREPARED J. Cooper PHONE (904) 795-6486
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

(SEE ATTACHED SUPPLEMENTARY INFORMATION SHEET)

POOR ORIGINAL

PHONE (904) 795-6486

1020 289

7 909250

483

Supplementary Information

Report No.: 50-302/79-081/031-0

Facility: Crystal River Unit #3

Report Date: 13 September 1979

Occurrence Date: 23 August 1979

Identification of Occurrence:

Control Complex Deluge/Sprinkler System inoperable contrary to Technical Specification 3.7.11.2.

Conditions Prior to Occurrence:

Mode 5 cold shutdown (0%)

Description of Occurrence:

At 0845, during the performance of Surveillance Procedure SP-365, Fire Pump Operability and Recirculation, it was discovered that fire service valve FSV-89 was closed. FSV-89 is the main isolation valve in the Deluge/Sprinkler Line leading to the Control Complex charcoal filter plenums. FSV-89 was immediately opened and sealed restoring system operability within .5 hour.

Designation of Apparent Cause:

The cause of this event can be attributed to person or persons unknown manually closing FSV-89 without proper authorization.

Analysis of Occurrence:

There was no effect to the plant or general public as the plant was in a cold shutdown condition and use of this system was not required for the period of time the valve was inoperable.

Corrective Action:

To preclude further recurrence, fire service valve FSV-89 was opened and a valve seal was used to seal the valve in the open position.

Failure Data:

This is the first reported occurrence of an event of this type.

/rc

1020 290