



Nebraska Public Power District

GENERAL OFFICE
P. O. BOX 499, COLUMBUS, NEBRASKA 68601
TELEPHONE (402) 564-8561

September 18, 1979

Director, Nuclear Reactor Regulation
Attention: Mr. Thomas A. Ippolito, Chief
Operating Reactors Branch No. 3
Division of Operating Reactors
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: IE Bulletin No. 79-07
"Seismic Stress Analysis of Safety-Related Piping"

Dear Mr. Ippolito:

Our responses to the subject bulletin dated April 24, 1979, June 29, 1979, and July 18, 1979 discussed the seismic reanalysis of the safety/relief valve (SRV) discharge piping at Cooper Nuclear Station. Recent discussions with the Staff have raised the question as to whether the SRV discharge piping will be verified to be in the as-built configuration.

This letter is to inform you that this piping was inspected under the requirements of IE Bulletin 79-14 September 14, 1979, during a recent unscheduled outage, and no nonconformances were discovered. The District's response to item no. 3 of IE Bulletin 79-14 will further summarize the results of this inspection.

If you have any additional questions on this matter, please do not hesitate to contact me.

Sincerely,

Jay M. Pilant
Director of Licensing
and Quality Assurance

JDW/cmk

1019 088

790925 0548

Handwritten: A00's 1/10