

Georgia Power Company
Post Office Box 4545
Atlanta, Georgia 30302
Telephone 404 522-6060

TIC
19810612:06
USING FEEDBACK
ATLANTA
Vogtle Project

September 7, 1979

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, GA 30303

REFERENCE:
RII: JPO
50-424
50-425
File: X7BC24
Log: GM-496

Attn: Mr. James P. O'Reilly

POOR ORIGINAL

Gentlemen:

The following is submitted in response to your letter dated July 11, 1979, concerning I.E. Bulletin 79-15.

Eight deep draft pumps, similar to those identified in the bulletin are utilized in the following safety related applications for each Vogtle Unit:

- 6 Nuclear Service Cooling Water Circulating Pumps (per unit)
- 2 Nuclear Service Cooling Water Transfer Pumps (per unit)

The manufacturer, model, capacity and plant application for the pumps are:

Nuclear Service Cooling Water Pumps
Manufacturer: Bingham - Willamette Company
Model: 18 x 27B VCM, 2 stage
Capacity: 8600 gpm, 230 TDH
Application: Cool various nuclear loads, ultimate heat sink

Nuclear Service Cooling Water Transfer Pumps
Manufacturer: Bingham-Willamette Company
Model: 8 X 12A VCR, 2 stage
Capacity: 600 gpm, 110 TDH
Application: Transfer water between cooling tower basins.

The overall dimensions of the pumps are:

1075 352

7910020189

OFFICIAL COPY

United States Nuclear Regulatory Commission
GM-496
September 7, 1979
Page 2


POOR ORIGINAL

Nuclear Service Cooling Water Circulating Pumps
Length: 94' - 3-3/4" Width: 3' - 5" (w/motor)

Nuclear Service Cooling Water Transfer Pumps
Length: 94' - 7/8" Width: 2' - 4" (w/motor)

The information requested in items 4, 5 and 6 of the bulletin pertaining to start-up and operational information is not applicable to Plant Vogtle.

Very truly yours,



Doug Dutton
Project General Manager

CMH:tp

xc: U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, DC 20555

M. D. Hunt - USNRC, Region II

J. H. Miller, Jr.
W. E. Ehrensperger
F. G. Mitchell, Jr.
C. F. Whitmer
R. J. Kelly
R. E. Conway
R. W. Staffa
J. T. Beckham, Jr.
K. M. Gillespie
C. W. Hayes
E. D. Groover
D. L. McCrary
R. A. Thomas
M. Z. Jeric
J. L. Vota

1075 353