

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | A L J M F 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 1 5

CONT

0 1 | X 6 0 5 0 0 0 3 4 8 7 1 0 1 1 7 9 0 1 0 1 9 7 9 0

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 | On October 11, 1979, Westinghouse Electric Corporation verbally notified Alabama

0 3 | Power Company that three (3) ASME Class 3 Valves (Q1E13V007A & B, Q1E21V304) were

0 4 | installed in ASME Class 2 piping systems. The subject valves are located in the

0 5 | CVCS and Containment Spray Systems. Tech. Spec. 6.9.1.8.i requires corrective action

0 6 | to prevent operation in a manner less conservative than assumed in plant design.

0 7 | The health and safety of the general public were not affected. No similar occurrences

0 8 | reported.

0 9 | S A 11 | B 12 | A 13 | V A L V E X 14 | X 15 | X 16

17 | 7 9 | 0 4 0 | 0 1 | T | 0

C 12 Z 19 | C 20 | Z 21 | 0 0 0 0 | N 23 | N 24 | N 25 | W 1 2 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 | A deficiency in the original plant design equipment specifications resulted in the

1 1 | purchase and installation of three (3) ASME Class 3 Valves into the ASME Class 2

1 2 | portion of a Class 2/Class 3 piping boundary. These valves are being replaced with

1 3 | valves which meet the design requirements. These valves will be replaced prior to

1 4 | leaving Mode 5.

1 5 | H 0 0 0 29 | NA 30 | D 31 | Notification from NSSS 32

1 6 | Z 33 Z 34 | NA 35 | NA 36

1 7 | 0 0 0 37 Z 38 | NA 39

1 8 | 0 0 0 40 | NA 41

1 9 | Z 42 | NA 43

2 0 | N 44 | NA 45

POOR ORIGINAL

7910230 463

NRC USE ONLY

NAME OF PREPARE: W. G. Hairston, III

PHONE: (205) 899-5156