

LICENSEE EVENT REPORT

CONTROL BLOCK: ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

⑦ ⑧ ⑨ 0 1 N C E P 2 ⑭ ⑮ 2 0 0 - 0 0 0 0 0 - 0 0 ⑳ ㉑ 3 4 1 1 1 1 ㉒ ㉓ 4 ㉔ ㉕ 5

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T

⑦ ⑧ 0 1 R ⑩ 0 5 0 - 0 3 2 4 ⑪ 7 0 9 2 6 7 9 ⑫ 1 0 1 6 7 9 ⑬

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

⑦ ⑧ 0 2 During normal plant operation, a "rod drift" alarm annunciated for rod 22-31. The

⑦ ⑧ 0 3 operator noticed that indication for its position, notch 48, was no longer illuminated

⑦ ⑧ 0 4 The position of rod 22-31 was verified by other available methods.

⑦ ⑧ 0 5 Technical Specifications 3.1.3.7, 6.9.1.9b

⑦ ⑧ 0 6

⑦ ⑧ 0 7

⑦ ⑧ 0 8

⑦ ⑧ 0 9 I D ⑪ E ⑫ A ⑬ I N S T R U ⑭ S ⑮ Z ⑯

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

⑰ 7 9 ⑱ 0 7 0 ㉑ 0 3 ㉒ L ㉓ 0

LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

⑳ X ㉑ X ㉒ Z ㉓ Z ㉔ 0 0 0 0 ㉕ N ㉖ Y ㉗ N ㉘ G 0 8 0

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPHD-A FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ⑳

⑦ ⑧ 1 0 An investigation determined that the problem was located in the PIP probe located in the

⑦ ⑧ 1 1 the drywell. This problem will be corrected during the next outage of sufficient

⑦ ⑧ 1 2 length. An Engineering Work Request has been written to determine if a generic

⑦ ⑧ 1 3 problem exists with this type of indication.

⑦ ⑧ 1 4

⑦ ⑧ 1 5 E ⑩ 0 5 6 ㉑ NA ㉒ A ㉓ Operator Surveillance

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

⑦ ⑧ 1 6 Z ㉑ Z ㉒ NA ㉓ NA ㉔ NA

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

⑦ ⑧ 1 7 0 0 0 ㉑ Z ㉒ NA

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

⑦ ⑧ 1 8 0 0 0 ㉑ NA

PERSONNEL INJURIES NUMBER DESCRIPTION

⑦ ⑧ 1 9 Z ㉑ NA

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

⑦ ⑧ 2 0 N ㉑ NA

PUBLICITY ISSUED DESCRIPTION

POOR ORIGINAL

1203 125 NRC USE ONLY

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-9521