

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

October 15, 1979

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

SEQUOYAH NUCLEAR PLANT UNITS 1 AND 2 - DELAY OF REACTOR TRIP BECAUSE
OF ARCING ACROSS UNDERFREQUENCY RELAY CONTACTS - NCR EEB 79-13 -
FINAL REPORT

The subject deficiency was initially reported to NRC-OIE Inspector
F. S. Cantrell on August 2, 1979, in accordance with 10 CFR 50.55(e).
Interim reports were submitted on August 27 and September 20, 1979.
Enclosed is our final report.

The corrective action associated with this deficiency is being imple-
mented for Watts Bar Nuclear Plant also.

If you have any questions concerning this matter, please get in touch
with D. L. Lambert at FTS 854-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager
Nuclear Regulation and Safety

Enclosure

cc: Mr. Victor Stello, Jr., Director (Enclosure) ✓
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

B019
5/11

1207 081