



NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

November 1, 1979

Mr J G Keppler, Director, Region III
Office of Inspection & Enforcement
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr Keppler:

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket No. 50-282 License No. DPR-42
50-306 DPR-60

Environmental Event Report 79-10
Cooling Tower Operations - October

Under TS B-5.4.2.A, we are furnishing two copies of this Environmental Event Report covering operation of the plant circulating water system in the partial recycle mode with daily average blowdown flow in excess of 150 cfs.

Daily average blowdown flow in excess of 150 cfs was required for only one day (October 10) during the month of October.

The higher flow was required to maintain cooling water inlet temperatures at less than 85°F.

Yours very truly,

E C Ward, PE
Manager-Nuclear Environmental Services

ECW/jh

cc: Director, NRR c/o DSB (17)
MPCA
Attn: J W Ferman

1274 230

7911080 269 P