

Duquesne Light

435 Sixth Avenue
Pittsburgh, Pa.
15219

(412) 456-6000

DUQUESNE LIGHT COMPANY
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15077

November 16, 1979
BVPS:JAW:742

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
LERs 79-44/03L, 79-49/01T

Mr. B. H. Grier, Director of Regulation
United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

In accordance with Appendix A, Beaver Valley Technical Specifications, the following Licensee Event Reports are submitted:

LER 79-44/03L, Technical Specification 4.7.7.2.a, Control room emergency air bottle below allowable pressure.

LER 79-49/01T, Technical Specification 3.4.6.1, Failure to obtain required grab sample of containment atmosphere.

Very truly yours,

J. A. Werling

for J. A. Werling
Superintendent

Attachments

1388 123

A002

S

1/1

7911230

244

S

Mr. B. H. Grier
November 16, 1979
BVPS:JAW:742
Page 2

cc: Director Of Management & Program Analysis
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. L. Wigginton, BVPS Licensing Project Manager
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. A. Beckman, Nuclear Regulatory Commission, King of Prussia, PA

G. A. Olson, Secretary, Prime Movers Committee - EEI

1388 124