

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 P A B V S 1 200-000000-00 341111 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE JO 57 CAT 58

CON'T
01 L 605000334 7101879 3111679 9
7 8 REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 At 0015 hours, the operator discovered the "D" air storage tank of the control
03 room emergency pressurization system below the allowable limits. The emergency
04 air tanks compressor, which had been filling the tank, had tripped on overload.
05 The compressor was restarted but failed to develop discharge pressure. The
06 control room pressurization air compressor, which is connected in parallel with
07 the emergency air tanks compressor, was out of service for an overhaul.
08

09 S G E B B L O W E R Z Z
7 8 9 SYSTEM CODE 9 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP. SUBCODE 14 VALVE SUBCODE 15

17 79 044 03 L 0
7 8 9 LER/RO REPORT NUMBER 21 22 EVENT YEAR 23 24 SEQUENTIAL REPORT NO. 25 26 OCCURRENCE CODE 27 REPORT TYPE 28 REVISION NO. 29

X D Z Z 0000 N Y A P 3 8 5
33 34 ACTION TAKEN 35 FUTURE ACTION 36 EFFECT ON PLANT 37 SHUTDOWN METHOD 38 HOURS 39 ATTACHMENT SUBMITTED 40 NRC-4 FORM SUB. 41 PRIME COMP. SUPPLIER 42 COMPONENT MANUFACTURER 43

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The incident resulted from a failed compressor. The emergency air tanks
11 compressor will receive a complete overhaul when parts become available. The
12 control room pressurization air compressor was returned to service and
13 repressurized the "D" air storage tank to the required pressure on 10/23/79.
14

15 E 048 N/A A Operator observation
7 8 9 FACILITY STATUS 10 % POWER 11 OTHER STATUS 12 METHOD OF DISCOVERY 13 DISCOVERY DESCRIPTION 14

16 Z Z N/A N/A
7 8 9 ACTIVITY CONTENT 10 RELEASED OF RELEASE 11 AMOUNT OF ACTIVITY 12 LOCATION OF RELEASE 13

17 0000 Z N/A
7 8 9 PERSONNEL EXPOSURES NUMBER 10 TYPE 11 DESCRIPTION 12

18 0000 N/A
7 8 9 PERSONNEL INJURIES NUMBER 10 DESCRIPTION 11

19 Z N/A
7 8 9 LOSS OF OR DAMAGE TO FACILITY TYPE 10 DESCRIPTION 11

20 N N/A
7 8 9 PUBLICITY ISSUED DESCRIPTION 10

NAME OF PREPARER J. A. Werling PHONE: 412-643-1258

1388 125

7911230 251

POOR ORIGINAL

NRC USE ONLY